

Pahala Wastewater
Treatment Plant
Preliminary Engineering
Report

Prepared for
County of Hawaii, Department of
Environmental Management
June 2018

Pahala Wastewater Treatment Plant Preliminary Engineering Report

Prepared for
County of Hawaii, Department of Environmental Management
June 2018



THIS WORK WAS PREPARED BY ME OR UNDER MY SUPERVISION.

A handwritten signature in black ink, appearing to read "C.C. Lekven".

April 30, 2020

Signature

Expiration Date of the License



1955 Main Street, Suite 200
Wailuku, Hawaii 96793

This page intentionally left blank.

Table of Contents

List of Figures	vi
List of Tables	vii
List of Abbreviations	ix
1. Introduction	1-1
1.1 Background	1-1
1.2 Existing System	1-1
1.3 Report Contents	1-1
2. Flow and Load Projections	2-1
2.1 Service Area	2-1
2.2 Flow Projections	2-3
2.3 Influent Characteristics	2-3
2.4 Influent Mass Loads	2-3
2.5 Mass Loads to the Environment via Existing LCCs	2-4
3. Effluent Management Options and Regulatory Requirements	3-1
3.1 Effluent Management Options	3-1
3.1.1 Ocean Discharge	3-1
3.1.2 Subsurface Disposal via Injection Wells	3-1
3.1.3 Water Recycling	3-1
3.1.4 Land Treatment	3-2
3.1.5 Drain Field	3-3
3.1.6 Recommendation	3-3
3.2 Treatment Requirements	3-3
4. Wastewater Treatment Evaluations	4-1
4.1 Preliminary Treatment	4-1
4.1.1 Screening	4-1
4.1.2 Influent Flow Measurement	4-2
4.1.3 Influent Flow Sampling	4-2
4.1.4 Preliminary Design of Headworks	4-2
4.1.5 Odor Control	4-4
4.2 Aerated Lagoon Treatment System	4-5
4.2.1 Aerated Lagoon Kinetics	4-5
4.2.2 Aeration in Lagoon Systems	4-5
4.2.3 Aerated Lagoon Configuration	4-7
4.2.4 Lagoon Liner	4-8
4.2.5 Lagoon Cover	4-9
4.2.6 Lagoon Sludge Management	4-11

- 4.3 Subsurface Flow Constructed Wetland 4-11
 - 4.3.1 Denitrification in Subsurface Flow Constructed Wetlands 4-11
- 4.4 Disinfection 4-12
 - 4.4.1 Calcium Hypochlorite 4-12
 - 4.4.2 Ultraviolet Light (UV) Disinfection 4-16
 - 4.4.3 UV System Design Summary 4-16
 - 4.4.4 Cost Evaluation 4-17
 - 4.4.5 Disinfection Recommendation 4-17
- 4.5 Effluent Management 4-17
 - 4.5.1 Design 4-18
- 4.6 Ancillary Systems 4-20
 - 4.6.1 Water 4-20
 - 4.6.2 Access Road 4-20
 - 4.6.3 Stormwater Management 4-21
 - 4.6.4 Pre-development Stormwater Conditions 4-21
 - 4.6.5 Electrical Systems 4-25
 - 4.6.6 Telemetry Systems 4-26
 - 4.6.7 Operations Building 4-26
 - 4.6.8 Site Fencing 4-26
- 5. Preliminary Design of Improvements 5-1
 - 5.1 Site Plan 5-1
 - 5.2 Process Schematic 5-1
 - 5.3 Design Criteria 5-4
 - 5.4 Environmental Benefits 5-6
 - 5.5 Cost Estimates 5-8
 - 5.6 Future Expansion 5-8
 - 5.6.1 Full Buildout Flows 5-8
 - 5.6.2 Improvements 5-8
- 6. Implementation 6-1
- 7. Alternative Treatment Options Evaluation 7-1
 - 7.1 Option Descriptions 7-1
 - 7.1.1 Option 1: Aerated Lagoons/Constructed Wetland/Land Application 7-1
 - 7.1.2 Option 2: R-1 Treatment/Land Application 7-1
 - 7.1.3 Option 3: R-1 Treatment/Seasonal Water Recycling 7-2
 - 7.1.4 Option 4: R-1 Treatment and Storage for 100% Water Recycling 7-4
 - 7.1.5 Option 5: Maximum Practical Treatment 7-6
 - 7.2 Cost Comparisons 7-7
 - 7.2.1 Capital Costs 7-7
 - 7.2.2 Operation and Maintenance Costs 7-7
 - 7.2.3 Recycled Water Sale Proceeds 7-8



7.2.4	Life-Cycle Costs.....	7-8
7.3	Non-Economic Discussion.....	7-9
7.3.1	Labor Requirements.....	7-10
7.3.2	Operational Complexity.....	7-10
7.3.3	Energy Consumption.....	7-11
7.3.4	Sludge Management.....	7-11
7.4	Living Machine®.....	7-11
7.5	Septic Tank Alternatives.....	7-12
7.5.1	Community Septic Tank.....	7-12
7.5.2	Converting LCC to Seepage Pit.....	7-12
7.5.3	Leachfield Disposal.....	7-13
7.5.4	Conversion to Individual Wastewater Systems.....	7-13
8.	Alternative Site Evaluation.....	8-1
8.1	Methodology.....	8-1
8.2	Site Locations.....	8-1
8.3	Criteria.....	8-3
8.4	Criteria Weighting Factors.....	8-7
8.5	Raw Scores.....	8-8
8.6	Weighted Analysis.....	8-9
8.7	Results.....	8-10
8.8	Conclusion.....	8-10
9.	References.....	9-1
	Appendix A: Cost Estimates.....	A-1

List of Figures

Figure 1-1. Pahala Existing Sewer Collection System and LCC Service Area.....	1-2
Figure 2-1. Pahala WWTP Service Area	2-2
Figure 3-1. Irrigation Demand Assessment.....	3-2
Figure 4-1. In-Channel Cylindrical Screen	4-2
Figure 4-2. Headworks.....	4-3
Figure 4-3. Activated Carbon Scrubber (GAC)	4-4
Figure 4-4. High Speed Floating Aerator	4-7
Figure 4-5. Normal Lagoon Configuration Schematic	4-7
Figure 4-6. Floating HDPE Shade Balls	4-10
Figure 4-7. Floating shade balls with current and turbulence in reservoir.	4-10
Figure 4-8. Subsurface Flow Constructed Wetland Concept	4-11
Figure 4-9. Typical Calcium Hypochlorite Feed System.....	4-13
Figure 4-10. Chlorine Contact Tank Configuration	4-15
Figure 4-11. Land Application System Schematic	4-19
Figure 4-12. Existing Drainage System.....	4-22
Figure 4-13. Flood Insurance Rate Map.....	4-24
Figure 4-14. Operations Building Preliminary Floor Plan	4-27
Figure 5-1. Preliminary Site Plan.....	5-2
Figure 5-2. Recommended Facility Process Schematic	5-3
Figure 5-3. Environmental Benefits of Proposed Project	5-7
Figure 7-1. Option 1 Schematic Diagram	7-1
Figure 7-2. Option 2 Schematic Diagram	7-2
Figure 7-3. Option 3 Schematic Diagram	7-2
Figure 7-4. Irrigation Demand Assessment.....	7-3
Figure 7-5. Option 3 Recycled Water Demand Assessment	7-3
Figure 7-6. Comparison of Irrigation Demands at Pahala and Kealakehe	7-4
Figure 7-7. Option 4 Schematic Diagram	7-5
Figure 7-8. Seasonal Storage Reservoir Analysis	7-6
Figure 7-9. Option 5 Schematic Diagram	7-7
Figure 7-10. Life-Cycle Costs of Options.....	7-9
Figure 7-11. Comparison of Electrical Energy Requirements	7-11
Figure 8-1. Pahala Site Alternatives	8-2

List of Tables

Table 2-1. Pahala WWTP Flow Projections	2-3
Table 2-2. Summary of Assumed Influent Characteristics	2-3
Table 2-3. Projected Influent Mass Loads.....	2-3
Table 2-4. Mass Loads to the Environment via Existing LCCs	2-4
Table 3-1. Applicable HAR 11-62 Land Disposal Requirements	3-3
Table 4-1. Normal Configuration Aeration and Mixing Requirements.....	4-8
Table 4-2. Lagoon Shade Ball Cover Application Parameters.....	4-9
Table 4-3. Calcium Hypochlorite Summary	4-13
Table 4-4. Chlorine Demand	4-14
Table 4-5. Chlorine Contact Tank.....	4-14
Table 4-6. UV Disinfection Design Summary.....	4-16
Table 4-7. Estimated Disinfection Costs	4-17
Table 4-8. Ultraviolet Disinfection – Advantages and Disadvantages.....	4-17
Table 4-9. Potential Land Application System Tree Species.....	4-18
Table 4-10. Potential Water Demands	4-20
Table 5-1. Preliminary Design Criteria	5-4
Table 5-2. Environmental Benefits of Proposed Project.....	5-7
Table 5-3. Pahala WWTP Order of Magnitude Construction Cost Estimate	5-8
Table 5-4. Pahala WWTP Full Buildout Flow Projections.....	5-8
Table 6-1. Implementation Schedule	6-1
Table 7-1. Summary of Capital Cost Estimates.....	7-7
Table 7-2. Summary of O&M Cost Estimates.....	7-8
Table 7-3. Summary of Annual Recycled Water Sale Proceeds.....	7-8
Table 7-4. Summary of Life-Cycle Cost Estimates	7-9
Table 7-5. Comparison of Operational Labor Requirements	7-10
Table 7-6. Comparison of Operator Certification Requirements per HAR 11-61	7-10
Table 8-1. Environmental, Social and Cultural Criteria	8-3
Table 8-2. Location and Site Characteristics	8-4
Table 8-3. Collection System and Service Area Criteria	8-5
Table 8-4. Land Use and Availability Criteria.....	8-6

Table 8-5. Relative Weighting Factors 8-7

Table 8-6. Alternatives Analysis – Raw Scores 8-8

Table 8-7. Alternatives Analysis – Weighted Scoring..... 8-9

Table 8-8. Alternative Site Ranking 8-10

List of Abbreviations

AB	aggregate base	Mgal	million gallons
AC	asphalt concrete	mm	millimeter
BMP	Best Management Practices	MSL	mean sea level
BOD ₅	5-day biochemical oxygen demand	N	nitrogen
CCH	City and County of Honolulu	NPV	net present value
cfs	cubic feet per second	O&M	Operation and Maintenance
COH	County of Hawaii	P	Phosphorus
CFR	Code of Federal Regulations	Psi	pounds per square inch
DNA	deoxyribonucleic acid	RNA	ribonucleic acid
DEM	Department of Environmental Management	ROW	right-of-way
DOH	Department of Health	scfm	standard cubic feet
ELLF	end-of-lamp-life	SCS	Soil Conservation Service
FIRM	Flood Insurance Rate Map	SR	slow rate
FOG	fats, oils, and grease	TSS	total suspended solids
ft ³	cubic feet	UIC	Underground Injection Control
FTE	full-time equivalent	USEPA	United States Environmental Protection Agency
GAC	granular activated carbon	UV	ultraviolet
gpm	gallons per minute	WQV	Water Quality Volume
H ₂ S	hydrogen sulfide	WWTP	Wastewater Treatment Plant
HAR	Hawaii Administrative Rules		
HDPE	high density polyethylene		
HELCO	Hawaii Electric Light Company		
hp	horsepower		
hp/Mgal	horsepower per million gallons		
hr	hour		
hp-hr	horsepower-hour		
L	liter		
lbs	pounds		
LCC	large capacity cesspools		
LPHO	low pressure high output		
MBR	membrane bioreactor		
Mg	milligrams		

This page intentionally left blank.

Section 1

Introduction

1.1 Background

The town of Pahala is located in the Kau district of the Island of Hawaii. According to the 2010 United States Census, the town population is approximately 1,350 persons.

The Pahala community was established as the result of the sugar operations of the C. Brewer Company. A portion of the community is serviced by a sewer system that was privately built, owned, and operated by the C. Brewer Company. The wastewater collected by the sewer system discharges into large capacity “gang” cesspools. Many years after its establishment, the private sewer system ownership was conveyed to the County of Hawaii (COH) Department of Environmental Management (DEM).

In 1998, the U.S. Environmental Protection Agency (USEPA), promulgated regulations, 40 Code of Federal Regulations (CFR) 144.14, that require the elimination of large capacity “gang” cesspools (LCCs). The County intends to construct a new sewer collection system located within public right-of-way (ROW) and replace the existing LCCs with a wastewater treatment plant to address the wastewater treatment and disposal needs of the Pahala community.

This report summarizes a proposed wastewater treatment plant (WWTP) needed in order to treat and dispose of the wastewater flow that is currently discharged to the LCCs, plus additional sewer connections. The report presents the existing and estimated future flows and loads to the treatment plant, the proposed treatment processes, recommendation for the WWTP upgrades needed to meet the future treatment needs, and an initial opinion of the cost to construct the improvements project.


1.2 Existing System

Figure 1-1 shows the collection system network and service areas for the LCCs. The collection system is a network of gravity sewers that discharge to two existing LCCs. A detailed analysis of the existing wastewater collection system was completed by others (M&E Pacific, December 2004). The report concluded that the Pahala community existing sewer system consists of about 3,000 linear feet of 6-inch diameter and 10,000 linear feet of 4-inch diameter pipelines. Residential laterals connect to 4-inch sewers that discharge into 6-inch sewer mains, predominately found in private property, which transmit wastewater to the LCCs. There are approximately 8 manholes in the sewer system. There are no pump stations and the system is not designed to collect stormwater.

1.3 Report Contents

Section 2 presents flow and load projections for the new WWTP. Section 3 evaluates effluent management options, and the treatment requirements for the preferred option. Section 4 presents evaluations conducted to develop the preliminary design of the proposed WWTP, which is presented in Section 5. An implementation plan is briefly presented in Section 6, followed by discussion of other treatment options that were considered and evaluated. The report concludes with a site selection consideration in Section 8.

This page intentionally left blank.



SCALE AS SHOWN
 JOB NO.: 150440

PAHALA WASTEWATER TREATMENT PLANT
 Pahala Existing Sewer Collection System and LCC Service Area

Section 2


Flow and Load Projections

This section summarizes the flow and load projections for the new WWTP.

2.1 Service Area


Within the town of Pahala, there is an existing wastewater collection that services approximately 109 properties. The collection system is currently located within easements in private properties and is treated and disposed through two LCCs. Figure 2-1 shows the service area for the new WWTP. The Kau Community Development plan indicates that the sewer system may eventually be expanded to service the entire community; however, the initial collection system and WWTP presented in this report will service the properties currently connected to the LCCs or located adjacent to the new collection system. Although this report does not include design for the full buildout service area, the proposed WWTP has been designed to accommodate modifications within the proposed 14.9-acre site for the anticipated future expansion of the service area.

This page intentionally left blank.



LEGEND

- Existing Condition to Large Capacity Cesspool (LCC)
- Initial Build Condition to WWTP Revised
- Future Buildout Condition to WWTP (Ka'u CDP Service Area)
- Proposed Pahala WWTP Site
- Pahala Future County Sewer System
- Existing Large Capacity Cesspool (LCC)



SCALE AS SHOWN
JOB NO.: 150440

PAHALA WASTEWATER TREATMENT PLANT
Pahala WWTP Service Area

FIGURE
2-1

2.2 Flow Projections

Wastewater flow projections were developed using the City and County of Honolulu's (CCH) current (2017) wastewater standards. Table 2-1 summarizes the flow projections.

Description	Value	Peaking Factor
Average dry weather flow	189,000 gallons per day	1.0
Peak day wet weather flow	662,000 gallons per day	3.5
Peak hour wet weather flow	630 gallons per minute	4.8

The WWTP will be designed to provide an average dry weather flow capacity of 190,000 gallons per day.

2.3 Influent Characteristics

The properties within the existing service area are primarily residential, but do include several commercial, apartment, and industrial zoned parcels. The wastewater characteristics of the WWTP influent are assumed to be similar to typical domestic wastewater. Table 2-2 provides a summary of the assumed influent characteristics.

Parameter	Value
5-day biochemical oxygen demand (BOD ₅)	300 mg/L
Total suspended solids (TSS)	300 mg/L
Total nitrogen	40 mg/L
Total phosphorus	7 mg/L

2.4 Influent Mass Loads

Table 2-3 summarizes the projected loads to the WWTP, based on the proposed average dry weather capacity of 190,000 gallons per day and the influent characteristics presented in Table 2-2.

Description	Value
BOD ₅	480 lbs./day
TSS	480 lbs./day
Total nitrogen	60 lbs./day
Total phosphorus	10 lbs./day

2.5 Mass Loads to the Environment via Existing LCCs

Currently, 109 properties discharge without treatment to two LCCs, as shown in Figure 2-2. These types of cesspools are a public health and environmental concern because of their likelihood of releasing disease causing pathogens and other contaminants, such as nitrate, to groundwater. The current annual mass loads to the environment via the existing LCCs based on the flow projections and assumed wastewater characteristics presented above are summarized in Table 2-4.

Table 2-4. Mass Loads to the Environment via Existing LCCs	
Parameter	Annual Load
BOD ₅	174,000 lbs./year
TSS	174,000 lbs./year
Total N	23,000 lbs./year
Total P	4,000 lbs./year

Section 3

Effluent Management Options and Regulatory Requirements

Effluent management options are evaluated in this section, followed by an assessment of regulatory requirements for the recommended effluent management system.

3.1 Effluent Management Options

Effluent management options are evaluated below.

3.1.1 Ocean Discharge

Ocean discharge of treated effluent is not considered a viable option for this small community due to the long distance to the shoreline (approximately 3 miles), high cost to construct an outfall, stringent receiving water quality standards, high receiving water monitoring cost due to the distance to Hilo harbor, and difficulty and length of time required to secure the required permits.

3.1.2 Subsurface Disposal via Injection Wells

Per Hawaii Administrative Rules (HAR), Title 11, Chapter 23, disposal to groundwater via an injection well is not allowed mauka of the State of Hawaii Department of Health (DOH) Underground Injection Control (UIC) line. Since the town of Pahala is located mauka of the UIC line, an injection well is not a viable option.

3.1.3 Water Recycling

An irrigation assessment was prepared to assess the viability of water recycling as the primary effluent management system, assuming the recycled water would be used to irrigate macadamia nut trees. Figure 3-1 is a summary of the assessment that shows there is typically no irrigation demand for six months of the year due to high rainfall. In addition, the DOH requires that all water recycling programs have a 100 percent backup disposal system in place to handle flow that does not meet recycled water quality standards or when recycled water supply exceeds demand. Therefore, water recycling is not a viable primary effluent management strategy for the community. However, water recycling treatment, storage, and distribution systems could be added in the future.




Figure 3-1. Irrigation Demand Assessment

3.1.4 Land Treatment

The USEPA defines land treatment as “the application of appropriately pre-treated municipal and industrial wastewater to the land at a controlled rate in a designed and engineered setting. The purpose of the activity is to obtain beneficial use of these materials, to improve environmental quality, and to achieve treatment goals in a cost-effective and environmentally sound manner” (USEPA, September 2006).

Land treatment systems rely on soil and vegetation to achieve treatment objectives, rather than energy-intensive mechanical equipment. As such, they are considered to be a form of “natural” treatment (Crites, et. al., 2014).

Land treatment is not a new concept. “Land application of wastewater was the first ‘natural’ technology to be rediscovered (after passage of the Clean Water Act of 1972). In the 1840s in England, it was recognized as avoiding water pollution as well as returning nutrients in wastewater back to the land. In the 19th century it was the only acceptable method for waste treatment, but it gradually slipped from use with the invention of modern devices” (Crites, et. al., 2014).

The soils at the proposed WWTP location are suitable for slow rate (SR) land treatment. SR land treatment consists of irrigation of land and vegetation with effluent. Significant treatment is provided as the water percolates through the soil. The vegetation uses the nutrients in the effluent as fertilizer, and transpires a portion of the applied water.

3.1.5 Drain Field

A drain field (i.e., leach field) could potentially be constructed for subsurface disposal of treated effluent. Preliminary assessment of the concept based on the site soil characteristics indicate approximately 20,000 linear feet of drain field trench would be required to accommodate the anticipated flow. It would be difficult to evenly distribute effluent throughout a drain field of this size. In addition, DOH regulations require a redundant drain field for subsurface disposal systems, making this option expensive to implement. This option is considered impractical for the community.

3.1.6 Recommendation

A slow rate land treatment system is recommended for effluent management for the community.

3.2 Treatment Requirements

The DOH regulates land treatment as “land disposal” per Hawaii Administrative Rules (HAR) 11-62. Table 3-1 lists the applicable effluent requirements for land disposal applicable to the project that were in effect at the time this report was prepared.

Table 3-1. Applicable HAR 11-62 Land Disposal Requirements		
Description	Value	HAR Reference
BOD ₅	30 mg/L monthly average 60 mg/L peak	11-62-26
TSS	30 mg/L monthly average 60 mg/L peak	11-62-26
Disinfection	Except for subsurface disposal systems, continuous disinfection of the treated effluent shall be provided	11-62-24
Setbacks	Treatment units shall be not less than 25 feet from property lines nor less than 10 feet from any building	11-62-23.1
Public accessibility control	6-foot-high fence surrounding treatment units	11-62-08

This page intentionally left blank.

Section 4

Wastewater Treatment Evaluations

This section presents the evaluations conducted in development of the proposed WWTP.

4.1 Preliminary Treatment

The preliminary treatment system will include screening, influent flow measurement, and influent sampling equipment.

4.1.1 Screening

Screening is recommended to protect the downstream system operations from large objects, debris, and rags that can be present in wastewater. Aerated lagoon treatment systems require a minimum of coarse screens to protect the aeration equipment. The industry trend is towards finer screening systems that remove greater amounts of debris from the waste stream; screens with 6-millimeter (mm) (¼-inch) openings are frequently used for activated sludge treatment systems. An aerated lagoon treatment system can benefit from ¼-inch screening to reduce the amount of floatable debris on the lagoon shoreline, creating a cleaner facility that is less attractive to birds. Since the Pahala WWTP will not be continuously staffed, a screening process requiring minimal attention is desirable. Furthermore, the screenings volume is expected to be small, subsequently screenings disposal is expected to be infrequent; weekly at most. Therefore, the screenings must be washed of organic debris to prevent the accumulation of nuisance odors and flies in the screenings barrel or bag between screening disposal events.

4.1.1.1 In-channel cylindrical screen

We recommend an in-channel cylindrical screen for this installation. The in-channel cylindrical screen combines screening, screenings washing, dewatering, compacting, and bagging/disposal within a single unit. The screening portion consists of an inclined screen basket inserted into the wastewater channel. The screening basket can consist of bars, perforated plates or sieves, depending on the application and clear opening required. The controls can be set to allow a mat to build up on the screening surface, allowing finer screening of the wastewater. Controlled by head loss, a rake arm starts rotating within the screen basket, pushing the screenings off the rake and into a perforated screenings hopper located at the screen's central axis. A shafted auger along the screen axis conveys the screenings from the hopper through an inclined tube, which dewateres and compacts the screenings. The tube includes a perforated dewatering section. The discharged screenings are about 40-percent dry, and can be discharged into a bin or directly into a bagging system. Figure 4-1 illustrates the process. Manufacturers include Lakeside and Huber. The key benefit to this system is the integrated screenings washing system, minimizing additional screenings handling and odor potential.

For this installation, the headworks will include two in-channel cylindrical screens, one will be on-line when the other is redundant, plus a bypass channel with manually cleaned bar rack.




Figure 4-1. In-Channel Cylindrical Screen

4.1.2 Influent Flow Measurement



Influent flow measurement is recommended to allow assessment of flows and loads to the biological treatment process, and to assess the biological treatment process performance. A Parshall flume will be provided upstream of the screening system to continuously record influent flow rates. Parshall flumes work well for influent measurement because the flume can operate in an open-channel configuration, can accommodate wide ranges of flows, and is self-cleaning. A straight approach length of at least 20 times the flume throat width will be provided upstream of the flume to provide favorable hydraulic conditions.

4.1.3 Influent Flow Sampling

An automatic refrigerated composite sampler is recommended to allow influent composite samples to be collected. Influent composite samples, when combined with influent flow measurement, can be used to calculate influent mass loading rates to the WWTP to assess the treatment performance and optimization of aeration rates in the biological treatment process. Periodic influent sampling is also recommended to monitor for changes in the influent characteristics.

4.1.4 Preliminary Design of Headworks

Figure 4-2 shows a plan and section of the proposed headworks. Influent wastewater will enter the upstream end of the headworks channel. Stop plates will be used to divert the flow to one of the two in-channel cylindrical screens, or to the manually-cleaned bar rack. The slide gates will be designed to allow automatic overflow to the other channels in the event of mechanical screen failure. The washed and compacted screenings will be deposited in a bag or 55-gallon drum for periodic disposal. The Parshall flume and automatic refrigerated composite sampler will be located upstream of the screens. The channels will be covered with fiberglass or aluminum plate to facilitate foul air collection, which will be conveyed to an odor control unit. In addition, a free-standing roof structure will be constructed over the headworks to protect the operators and equipment from rain and sun.



SCALE:
JOB NO: 150440

PAHALA WASTEWATER TREATMENT PLANT
HEADWORKS

FIGURE
4-2

4.1.5 Odor Control

A notorious location for foul odor is the headworks of a wastewater treatment plant. This odor is caused by hydrogen sulfide (H_2S), which is formed under anaerobic conditions of the wastewater collection system. Due to H_2S low solubility in wastewater, when there is an excessive concentration of H_2S in the wastewater or if there is turbulence, H_2S gas escapes into the atmosphere. This release produces the distinct rotten egg smell. In addition to H_2S , there are other foul odorous compounds that can be released from wastewater, such as ammonia, amines, diamines, mercaptans, skatole, and organic sulfides.

Treatment of foul odors can be approached in two ways: preventing odors through liquid treatment or controlling odors in the gas phase. While liquid treatment provides control of odors prior to their release, gas phase treatment involves the collection and treatment of gases once they have been released from wastewater. Treatment methods can be aimed at one type of odor, or can treat a range of odors.

4.1.5.1 Granular Activated Carbon

A granular activated carbon (GAC) scrubber is recommended for the Pahala WWTP headworks. A GAC scrubber passes odorous air through a bed of activated carbon, which adsorbs the odorous constituents within the pore spaces of the carbon.

Chemical oxidation or reduction of some compounds can also occur. As pore spaces become occupied, efficiency degrades, and the carbon must be replaced or regenerated. Carbon is most effective on higher molecular weight molecules such as the organic sulfur compounds, which makes it the technology of choice. Package GAC scrubbers are available for small headworks and vessels can be situated vertically, horizontally, or radially to optimize footprints and reduce structure elevation profiles. Figure 4-3 illustrates the process. The County currently operates GAC scrubbers at other facilities, and purchases the GAC media in bulk to reduce costs.




Figure 4-3. Activated Carbon Scrubber (GAC)

4.2 Aerated Lagoon Treatment System

The biological wastewater treatment needs at the Pahala WWTP will be met by a series of aerated lagoons. A floating cover will be installed on the last cell to reduce algae in the effluent. The preliminary design of the aerated lagoon treatment system is developed in this section.

4.2.1 Aerated Lagoon Kinetics

The Pahala WWTP design is reliant on partial mix aerated lagoon environments to provide the community's wastewater treatment needs for the initial buildout condition. Partial mix aerated lagoon kinetics are described below.

4.2.1.1 Partial mix model

Partial mix aerated lagoons are based on the concept of allowing solids to settle in lagoons while providing only enough aeration and mixing to meet the oxygen requirements of the naturally occurring micro-organisms in the system. The solids tend to settle in areas of the lagoon that are subject to less mixing energy, where they anaerobically decompose. Infrequent sludge removal is required to maintain sufficient lagoon treatment volume.

Removal of BOD₅ in partial-mix aerated lagoons depends on the hydraulic detention time. The design model for partial mixed ponds of equal size in series is (Crites, et. al., 2006):

$$\frac{C_n}{C_o} = \frac{1}{[1 + (kt/n)]^n}$$

Where C_n = effluent BOD₅ concentration in cell n , mg/L
 C_o = influent BOD₅ concentration, mg/L
 k = partial-mix first-order reaction rate constant, day⁻¹
 t = total hydraulic residence time in the lagoon system, day
 n = number of cells in the series

If the lagoons in a system are of unequal size, then the equation must be applied to each lagoon in the series. The Ten-States Standards recommends using a value of 0.276 day⁻¹ at 20 °C for the reaction rate constant (Great Lakes – Upper Mississippi River Board, 1997).

4.2.1.2 Mixing in Lagoon Systems

The energy required for mixing in aerated lagoon systems is generally provided by the aeration system. For partial mix systems the aeration system is sized to provide enough oxygen to maintain aerobic conditions and no more. For mechanical aeration systems energy input of at least 30 horsepower per million gallons (hp/Mgal) of lagoon volume is required to keep solids in suspension (Rich, 1999).

4.2.2 Aeration in Lagoon Systems

Oxygen requirements in aerated lagoon systems are based on the organic loading entering the cell. Supplying oxygen at a rate of 1.5 times the BOD₅ mass entering the cell has been found to be sufficient to treat the wastewater. The following equation is used to estimate the oxygen transfer rate (Crites, et. al., 2006):

$$N = \frac{N_a}{\alpha \left[\frac{(C_{sw} - C_L)}{C_S} \right] (1.025)^{(T_w - 20)}}$$

Where N = Equivalent oxygen transfer to tap water at standard conditions (lbs/hr)

N_a = Oxygen required to treat the wastewater (lbs/hr)

α = (oxygen transfer in wastewater)/(oxygen transfer in tap water)

$C_{sw} = \beta(C_{ss})P$ = oxygen saturation value of the waste, mg/L

β = wastewater saturation value/tap water oxygen saturation value = 0.9

C_{ss} = tap water oxygen saturation value at temperature T_w

F = ratio of barometric pressure at the site to barometric pressure at sea level

C_L = minimum dissolved oxygen concentration to be maintained

C_S = oxygen saturation value of tap water at 20°C and 1 atm pressure

T_w = wastewater temperature, °C

Oxygen can be supplied to aerated lagoon systems using mechanical aerators or diffused aeration systems. Mechanical aerators are commonly rated by the number of pounds of oxygen the units will supply under standard conditions per horsepower-hour (lbs. O₂/hp-hr). Diffused air requirements are calculated using the following equation (Crites and Tchobanoglous, 1998):

$$Q_{air} = \frac{W_{oxygen}}{(AOTE)(O_2)(\gamma_{air})(1440)}$$

Where Q_{air} = Required air flow (ft³/min)

W_{oxygen} = Oxygen requirements (lbs/day)

$AOTE$ = Actual oxygen transfer efficiency, expressed as a fraction

O_2 = Fractional percent of oxygen in air by weight (0.2315)

γ_{air} = Specific weight of air (0.075 lbs/ft³ at 1 atmosphere and 20°C)

The oxygen transfer efficiency of a diffused air system is a function of the air bubble size and the depth of the water column. Smaller air bubbles result in higher oxygen transfer efficiencies than larger bubbles, as do diffusers that are set at deeper depths within the water column.

4.2.2.1 High speed floating aerators

High-speed floating aerators are commonly used for aerated lagoon systems. The units consist of a motor and impeller attached to a float. The units are typically anchored to the lagoon shore using cables. High-speed floating aerators are designed to pump water from the lagoon and spray it into the air, allowing oxygen to diffuse into the water droplets. The high-speed floating aerators can be

outfitted with draft tubes to enhance deep water lagoon mixing or anti-erosion plates to ensure water is drawn from the surface. Figure 4-4 shows a typical high-speed floating aerator.



Figure 4-4. High Speed Floating Aerator

Advantages of this system include low capital costs, relatively high oxygen transfer efficiency, good mixing efficiency, and simple operation and maintenance. The chief disadvantage of the system is the creation of aerosols as the lagoon water is sprayed into the air.

Manufacturers of this type of aerator include Aqua-Aerobics, Aerator Products and Europlec/Aeromix Systems Inc.

High-speed floating aerators are recommended for the Pahala WWTP due to their relatively high oxygen transfer efficiency, low capital cost, and simple operation and maintenance. High-speed floating aerators are easy to remove from service, and can be easily moved between lagoons or cells, if needed.

4.2.3 Aerated Lagoon Configuration

The normal operating condition for the Pahala WWTP will be to operate the four lagoon cells in series as partial mix environments. Figure 4-5 is a schematic representation of the normal operating mode. The fourth cell will be outfitted with a floating cover to preclude algae growth. Having four lagoons will allow the County to take a lagoon out of service for maintenance.




Figure 4-5. Normal Lagoon Configuration Schematic

Table 4-1 summarizes the results of the aeration and mixing calculations for the normal operational configuration treating the design average dry weather flow rate of 190,000 gallons per day. Comparison of the minimum aerator requirements shown in Table 4-1 with the proposed aerator layout shown in Figure 4-4 reveals that the aerator power supplied exceeds the minimum requirements. An aerator control system will be provided that will intermittently turn the aerators on and off in accordance with the operator settings to supply sufficient oxygen to the system.

Table 4-1. Normal Configuration Aeration and Mixing Requirements					
Cell	Volume (gal)	Influent BOD₅ (mg/L)	Effluent BOD₅ (mg/L)	Minimum Aerator Requirement (hp)	Mixing Density (hp/Mgal)
1	80,000	300	139	27	34
2	80,000	139	64	13	16
3	80,000	64	30	6	7
4	80,000	30	<30	2	3

4.2.4 Lagoon Liner

Lagoon liners are required to prevent wastewater seepage into the ground. The liner will be exposed to sunlight, so resistance to ultraviolet light (UV) degradation is a key factor in the selection of the liner material, as is the compatibility of the material with typical domestic wastewater characteristics and ease of liner maintenance. An 80-mil textured high density polyethylene (HDPE) geomembrane is recommended for this application.

Textured HDPE is known to have excellent UV resistance, good chemical resistance, and generally is not affected by fats, oils, and grease (FOG). Maintenance of HDPE requires a specialty contractor who can complete fusion weld repairs. Unlike smooth HDPE, textured HDPE presents minimal slipping hazard to operations personnel. Furthermore, the anticipated useful service of an HDPE liner in typical Hawaii municipal wastewater treatment conditions is 25 to 30 years.

4.2.5 Lagoon Cover

In the normal operating mode, the final cell in the lagoon series will be covered in order to deprive algae of sunlight. This will reduce the algae concentration, which can increase total suspended solids (TSS) levels in the system effluent. The cover should float on the surface of the water, be UV resistant, suitable for windy environments, and allow for rainwater to pass through the cover to prevent ponding. A floating shade ball cover is proposed for this installation.

Floating shade balls covers have been used for decades in the mining, water and wastewater treatment industries. Figure 4-6 shows the design elements of a typical shade ball, and Figure 4-7 shows how shade balls provide cover on a reservoir. In addition to reducing algae growth, shade ball covers deter waterfowl from storage ponds. The black, UV-stable HDPE resin has known to withstand a range of challenging chemical and environmental conditions. Table 4-2 summarizes technical data for the balls.

Table 4-2. Lagoon Shade Ball Cover Application Parameters	
Requirement	Description
Algae Control	Balls - 90% shade coverage
Temperature	50°C to 95°C
Wind Resistance	Balls ballasted with potable water tested in winds of 120 mph (category 3 hurricane)
Waterfowl Safety	Waterfowl do not recognize ball-covered pond as a water body and will not nest on the unstable surface
Lifecycle/Warranty	The shade balls are warranted for 10 years, with an expected resin life of 25+years
Operations and Maintenance	Self-cleaning, self-levelling and require little to no maintenance Balls will move out of the way of maintenance barge, and can be restrained with booms Little installation effort required Precipitation does not affect the cover
Sustainability	Resin is recyclable, paraben free and suitable for drinking water applications Ballast is potable water Resin can be made from recycled plastic
Environment	Balls have been installed in chemically harsh environments (mining industry), in drinking water reservoirs, and in tropical locations Balls reduce algae formation and corresponding disinfectant byproducts in chlorination applications




Figure 4-6. Floating HDPE Shade Balls



Figure 4-7. Floating shade balls with current and turbulence in reservoir.

4.2.6 Lagoon Sludge Management

Partial-mix aerated lagoons are designed to allow solids to settle to the bottom of the lagoon, forming a sludge layer. The sludge slowly anaerobically digests in the bottom of the lagoon. The mechanical aerators in the lagoon maintain an aerobic water cap at the surface of the lagoon that oxidizes any odors that are released from the anaerobic sludge layer at the bottom of the lagoon. Sludge is removed infrequently, typically every 15 to 30 years, when the sludge blanket thickness begins to affect treatment performance or in conjunction with lagoon liner replacement. Aerated lagoon operators typically monitor sludge blanket thicknesses semi-annually to assess sludge accumulation.

Sludge removal contractors are typically employed to dredge the solids, dewater, and haul to a landfill for disposal. Sludge from aerated lagoons is typically not offensive when dewatered due to the long residence time in the bottom of the lagoon.

Alternatively, the sludge can be recycled if a permitted land application site is available and the sludge meets State and Federal requirements for land application or composted with green waste at a permitted composting facility.

4.3 Subsurface Flow Constructed Wetland

A subsurface flow constructed wetland is recommended to provide additional treatment and polishing of the aerated lagoon effluent. It is anticipated that the aerated lagoon system will convert ammonia that is present in the wastewater influent into nitrate via a process called nitrification. A subsurface flow constructed wetland will remove this nitrogen from the wastewater via a process called denitrification. Reduction of nitrogen loading through the constructed wetland will decrease the area required for overland flow effluent management.

Subsurface flow wetlands consist of shallow lined basins that are filled with gravel media and planted with emergent wetland vegetation. Water is introduced to the gravel media layer and flows horizontally through the basin. The water level in the wetland is maintained below the gravel surface at all times. Treatment occurs through physical, chemical, and biological mechanisms as the water flows horizontally through the gravel media bed. Figure 4-8 is an illustration of the concept.




Figure 4-8. Subsurface Flow Constructed Wetland Concept

4.3.1 Denitrification in Subsurface Flow Constructed Wetlands

Denitrification is a biological process whereby nitrate molecules are transformed into nitrogen gas molecules by naturally-occurring bacteria. The denitrifying bacteria require five conditions for the process to occur:

- A place to grow.

- A source of nitrate.
- An anoxic (low-oxygen) environment.
- A source of carbon.
- Adequate water temperature.

The equation used to predict denitrification in subsurface flow constructed wetlands is shown below (Crites, et.al., 2014).

$$\frac{C_e}{C_o} = \exp(-K_T t)$$

where:

C_e = effluent nitrate-nitrogen concentration (mg/L)

C_o = influent nitrate-nitrogen concentration (mg/L)

K_T = temperature-dependent rate constant = $1.00(1.15)^{(T-20)}$ days⁻¹ when $T > 1^\circ\text{C}$

t = hydraulic residence time (days)

Subsurface flow constructed wetlands are capable of providing additional treatment benefits beyond nitrogen reduction, such as removal of organic carbon, suspended solids, phosphorus, metals, trace organics, and pathogens. The additional treatment benefits are not primary design parameters, but should be considered as additional polishing treatment benefits that may be realized for the Pahala WWTP.

4.4 Disinfection

Disinfection processes selectively kill pathogens or render them incapable of reproduction or harm to humans. Disinfection at WWTPs is employed for the purposes of protection of public health, reduction of organic matter, inorganics, nutrients, odor, aesthetics, and maintaining waste-assimilative capacity of receiving water bodies. The protection of public health through the control of disease-causing microorganisms is the primary reason for wastewater disinfection (WEF, 1996). As the last barrier of protection from pathogenic organisms, disinfection at WWTPs is an important process. To address disinfection, both a calcium hypochlorite system and a UV system were evaluated.

4.4.1 Calcium Hypochlorite

Calcium hypochlorite is the most common solid form of hypochlorite used for disinfection. It can be found as a powder, granules, pellets, or as tablets in concentrations up to 70 percent. Calcium hypochlorite will degrade in strength at a rate of 3 to 5 percent per year. Once applied to the wastewater, the chemistry is similar to that for sodium hypochlorite. Calcium hypochlorite decomposes in an exothermic reaction if exposed to moisture.

The solid can be directly applied to wastewater at very small WWTPs. Figure 4-9 shows a typical calcium hypochlorite feed system.




Figure 4-9. Typical Calcium Hypochlorite Feed System

The advantages of using calcium hypochlorite for disinfection at small, remote WWTPs is that it is available in concentrated form as powder, pellets, or tablets. This makes the transportation and storage of disinfectant optimal for small WWTPs. Table 4-3 summaries calcium hypochlorite characteristics.

Table 4-3. Calcium Hypochlorite Summary	
Description	Characteristic
Transported form	Solid
Typical transported concentration	70%
Largest transported volume available	55 lb. pails
Decay Rate	Decays 3-5% per year
pH	N/A
Hazards	Toxic if ingested (usually through dust or liquid form)
Storage constraints	Must be stored in a cool, dry, dark place
Special equipment	Tablet feeder
Particular issues	Heats and combusts if not stored properly Scaling in pipes, Off gassing

4.4.1.1 Dose and Contact Time

The effectiveness of a chlorination system is highly dependent on the characteristics of the wastewater, the initial mixing and contact time, and the chlorine dose used. For nitrified effluent, the recommended dose is between 8 and 18 mg/L. The WWTP will discharge to a land application system during normal flow and wet weather periods when the secondary effluent will be diluted by precipitation falling onto the overland flow terraces. For planning purposes, a 10 mg/L dose was assumed to be sufficient for the WWTP for most circumstances, but equipment will be sized to

provide chemical feed at a rate of up to 100 lbs./day, which will ensure an adequate chlorine dose for peak wet weather discharge flows.


Table 4-4 lists the chlorine demand for various flow conditions.

Table 4-4. Chlorine Demand		
Description	Flow	Chlorine Demand
Average dry weather flow	0.19 mgd	16 lbs./day
Peak day wet weather flow	0.662 mgd	55 lbs./day

The recommended minimum contact time for chlorination is 15 minutes (Ten States Standards Wastewater, Recommended Standards for Wastewater Facilities, 1997, Great Lakes – Upper Mississippi River Board of State and Provincial Public Health and Environmental Managers). The size of the chlorine contact tank will need to accommodate a 15-minute contact time for the peak discharge rate. For this application, the peak discharge rate will be equal to the peak day wet weather flow, due to the flow equalization provided by the aerated lagoons. Table 4-5 summarizes the contact tank dimensions, while Figure 4-10 shows a conceptual contact tank configuration.

Table 4-5. Chlorine Contact Tank	
Description	Value
Peak discharge rate	460 gpm
Minimum chlorine contact tank	15 minutes
Tank volume required	920 cubic feet
Channel water depth	5 feet
Channel width	3 feet
Tank channel total length	61 feet
Tank dimensions including channel walls	13 feet x 24 feet

Path: P:\Projects\Hawaii, County Of (HI)\150440 COH Pahala WWTP\CAD\10-PROJECT\FIGURES
File Name: 150440-FIG-ChlorContactTank Plot Date: March 22, 2018 4:32 PM Cadd User: Richard Sellona



SCALE: Field
JOB NUMBER: 150440

PAHALA WASTEWATER TREATMENT PLANT
CHLORINE CONTACT TANK
CONFIGURATION

FIGURE
4-10

4.4.2 Ultraviolet Light (UV) Disinfection

A common alternative to a chlorine disinfection is ultraviolet light (UV). Ultraviolet systems destroy microorganisms by affecting their deoxyribonucleic acid (DNA) and ribonucleic acid (RNA) and impeding their ability to reproduce. A UV disinfection system is comprised of lamps, a reactor, and control panel. Wastewater can flow either parallel or perpendicular to the lamps in the reactor, while the control box provides a starting voltage and maintains the continuous current needed. Currently, most systems are equipped with an automated lamp cleaning system, to maintain lamp efficiency levels.

A UV system's effectiveness is dependent on the characteristics of the wastewater, the dose, and the exposure time. In the case of UV radiation, the most important factor is the transmittance of the water, which has a direct effect on the ability of UV light to penetrate through the liquid and reach microorganisms present at the required intensity. Ideally, the discharge undergoing treatment should not have a transmittance lower than 55 percent, with the intensity decreasing the farther the microorganisms are from the lamp. The optimum wavelength to effectively inactivate microorganisms is between 250 and 270 nanometer.

The main types of UV lamps used for wastewater disinfection are conventional low-pressure lamps, low pressure high output (LPHO) lamps and medium pressure lamps. Several UV systems include lamps with automated sleeve cleaning.

4.4.3 UV System Design Summary

A UV disinfection system requires a about the same size footprint as chlorine. Disinfection occurs as the organism is exposed to the UV radiation as the water flows past the UV lightbulbs. The Trojan UV3000+ system is used at numerous facilities across the US, including some treatment plants in Hawaii. The estimated cost included in this report are based on an assumed UV transmittance of 65 percent. The amalgam lamp used with the UV3000+ system has an end-of-lamp-life factor (ELLF) of 0.98 indicating little loss in UV light output over the life of the lamp. This ELLF has been tested and approved by the State of California and is also accepted by the State of Hawaii for reuse applications. The system would use LPHO lamps with automatic sleeve cleaning. LPHO lamps are energy efficient and the UV300+ system is furnished with automatic sleeve cleaning devices to reduce labor requirements. Each UV lamp is enclosed in a quartz sleeve to separate it from the water medium. Each lamp draws 254 watts at full output and is driven by electronic ballast. The electronic ballast allows the lamps to be dimmed to conserve power based on a control signal from a flow meter. The LPHO lamps will have a minimum life of 12,000 hours when operated in an automatic mode and limited to a maximum of 4 on/off cycles per 24 hours. Table 4-6 summarizes the size and design criteria for the UV system required to treat the WWTP discharge.

Table 4-6. UV Disinfection Design Summary	
Description	Value
Peak Hour Wet Weather Discharge	630 gpm
Minimum UV transmittance	65 percent
No. of UV channels	1
Design dose	35,000 μ Ws/cm ²
Disinfection limit	30 e-coli per 100mL
Validation factors	0.98 end of lamp factor

4.4.4 Cost Evaluation

A summary of capital and life-cycle estimated costs for both chlorination and UV disinfection is presented in Table 4-7 for comparison.

The capital costs include the materials and equipment costs, construction costs, electrical, instrumentation and control, soft costs, and contingency. As shown in the table, the UV option incurs higher capital costs. The life cycle costs look at the impact of the capital costs along with the annual operations and maintenance costs, including power, materials, chemicals, and labor costs over the next 30 years. The life-cycle costs for chlorination option appear to be about 78 percent of the UV option.

Description	Chlorination	UV System
Capital Cost	\$200,000	\$800,000
Annual Operations and Maintenance	\$15,000	\$6,000
Life-cycle Cost (30-Year Net Present Value)	\$746,000	\$947,000

4.4.4.1 Non-Economic Evaluation

Table 4-8 presents a summary of advantages and disadvantages of using an ultraviolet light for disinfection.

Advantages	Disadvantages
Effective at inactivating most viruses, spores, and cysts	Low dosage may not be effective on some pathogens and some organisms can repair and reverse the destructive effects of UV
It's a physical process, instead of chemical – it eliminated the need to transport, handle, store toxic or corrosive chemicals	Turbidity and TSS in the wastewater can reduce UV disinfection effectiveness
No harmful residual compounds created that are toxic to humans or aquatic life	Will likely require more call-outs by operators due to alarms caused by “dirty power”.
Shorter contact time (less than a minute)	The relative intensity of equipment maintenance requirements, including staffing training and on-island availability.

4.4.5 Disinfection Recommendation

A tablet chlorination system is the recommended disinfection option over the UV system for the WWTP because it incurs lower capital and lifecycle costs. In addition, tablet chlorination will be more-reliable than UV due to frequent “dirty power” conditions on the island.

4.5 Effluent Management

For effluent management, a slow-rate land application system is proposed. The concept is to intermittently apply wastewater to crops growing in permeable soils. As the applied water percolates through the soil matrix or is taken up by the crop, it is treated by physical filtration and by biological

mechanisms. After an application period or wetting period, the surface can dry and oxygen can enter the soil matrix, which aids aerobic biological treatment. The frequent wetting and drying also maintains the infiltration rate through the soil surface and minimizes soil clogging. This method of land application is an effective treatment process for BOD₅, TSS, trace organics, phosphorus, metals and pathogen removal. Furthermore, removal of nitrogen can be significant when system is managed for that objective.

4.5.1 Design

The slow-rate system site consists of a net area of approximately 5.5 acres. The 5.5 acres will be divided into 4 small groves of native trees, so that water application will be rotated to a different grove each day. An additional small grove will be utilized as an emergency (overflow) or reserve when surface or distribution system maintenance is conducted. By using one grove per day the wet/dry cycle will be 1-day wetting and 3-days drying.

The groves will be planted with native Hawaiian trees. Trees grown within the land application area will need to be water tolerant. Table 4-9 lists potential native tree species.


Table 4-9. Potential Land Application System Tree Species

Common Name	Genus Species	Salt Tolerance	Water Requirements	Rubbish and Maintenance	Preferred Elevation
Milo	<i>Thespesia populnea</i>	Very	Dry to Wet	Moderate	Low to Medium
Loulu	<i>Pritchardia hillebrandii</i>	Very	Dry to Wet	Low	Low
Aalii	<i>Dodonaea viscosa</i>	Very	Dry to Medium	Low	Low to High
Kou	<i>Cordia subcordata</i>	Very	Dry to Wet	Moderate	Low
Golden Loulu	<i>Pritchardia arecina</i>	Moderate	Dry to Wet	Low	Low to Medium
Wiliwili	<i>Erythrina sandwicensis</i>	Moderate	Dry to Medium	Moderate	Low


The distribution system will consist of gated piping located on the surface. The piping will have slots to allow the applied wastewater to uniformly be distributed over the grove surface. A perimeter fence will be installed to limit access. Access roads will surround each grove. Figure 4-11 reflects the proposed land application schematic.

This page intentionally left blank.


Path: P:\Projects\Hawaii, County Of (HI)\150440 COH Pahala WWTP\CAD\0-PROJECT\FIGURES
File Name: 150440-FIG-LandAppSystem Plot Date: May 22, 2018 5:25 PM Cadd User: Richard Sellona



PLAN



SECTION A - A'



SCALE: 1" = 100'
JOB NO: 150440

PAHALA WASTEWATER TREATMENT PLANT
LAND APPLICATION SYSTEM SCHEMATIC

FIGURE
4-11

4.6 Ancillary Systems

4.6.1 Water

Potable water is not currently available at the site. The nearest potable water system is located uphill in town. Table 4-10 provides an initial assessment of the potential water demands at the WWTP. The water demands are either for process or potable uses. As shown in the table, the process water demands are significantly greater than the potable demands.

Description	Flow Rate	Type	Priority
Screenings washer	20 gpm for 10 min/hour 4,800 gpd	Process	Mandatory with screen
Hose bibs	10 gpm for 20 min/day 200 gpd	Process	Desirable to maintain facility
Emergency eye wash / shower	20 gal per use	Potable	Mandatory
Restroom	20 gpd	Potable	Recommended

To supply water to the WWTP, it is recommended to construct approximately 2,000 linear feet of pipe from the intersection of Huapala Street and Maile Street to the site and install a 1-inch water meter with 1 ½-inch backflow preventer.

A plant water system will be supplied by the County water meter. The on-site water system will be split into two branches, one for process water and one for potable water. The potable water will service the restroom and emergency eye wash/shower. A second backflow preventer will separate the process water uses from the potable connections.

4.6.2 Access Road

All weather access will be required to operate and maintain the WWTP. Access to the site will be provided by connection to Maile Street. A paved driveway apron is proposed at Maile Street and an all-weather driveway will extend into the site and provide access to and around the various WWTP infrastructure. Additionally, a turn-around area large enough to accommodate a fire truck will be provided.

Access road pavement options include aggregate base (AB) gravel, asphalt concrete (AC), or concrete. AB is the lowest cost option, but requires the most maintenance. AC pavement is not recommended for steep (greater than 12 percent) grades. Concrete is the highest cost option, but is the most durable and requires the least maintenance.

The recommended driveway pavement section is 2-inches of AC over 6-inches of aggregate base course. For portions of the driveway that exceed 12 percent slope, a concrete pavement section is recommended.

4.6.3 Stormwater Management

The overall goal of stormwater management is to mitigate the adverse impact of new construction on the environment. Stormwater management can generally be separated into two areas:

1. Stormwater Quantity: management of the quantity to prevent increased flows and volumes leaving the site on the downstream watercourses.
2. Stormwater Quality: management of the quality of stormwater runoff to prevent contaminants such as silt, trash, hydrocarbons, heavy metals, and pesticides from leaving the site through stormwater runoff.

4.6.4 Pre-development Stormwater Conditions

4.6.4.1 On-site

The majority of the proposed 42.5-acre site is currently utilized as macadamia nut orchards, consisting of trees or unimproved agricultural roads. The parcel is bound on two sides by improved county and state right-of-way and to the east by additional macadamia nut orchards.


The existing elevations range between 580 to 780 feet above mean sea level (MSL) and slopes in the southerly direction at an average rate of 8 percent. The soils in this area are described as Naalehu medial silty clay loam (NaC) by the Soils Conservation Service (SCS). These soils are considered well drained with low runoff and slight erosion hazard.

On-site stormwater run-off generally sheet flows in a southerly direction to off-site swales along the roadway frontages, Maile Street and Hawaiian Belt Road (also known as Mamalahoa Highway). There is no known on-site drainage collection system, see Figure 4-12.

4.6.4.2 Off-site

Swales that run and collect along the roadway frontages of the property are conveyed through a box culvert at the intersection of Maile Street and Hawaiian Belt Road and discharged makai. Similarly, running along the north property line is an abandoned concrete flume, which was previously utilized to discharge process water from the adjacent old sugar mill to agricultural land makai of Hawaiian Belt Road. Figure 4-12 conceptualizes the existing drainage system.

Path: P:\Projects\Hawaii, County Of (HI)\150440 COH Pahala WWTP\CAD\0-PROJECT\FIGURES
File Name: 150440-FIG-ExistingDrainageSystem Plot Date: June 18, 2018 10:45 AM Cadd User: Richard Sellona



SCALE: 1" = 200'
JOB NO: 150440

PAHALA WASTEWATER TREATMENT PLANT
EXISTING DRAINAGE SYSTEM


FIGURE
4-12

4.6.4.3 Flood Hazards


The subject property flood zone is designated Zone X, area of minimal flood hazard corresponding to areas outside of the five-hundred-year flood plain, as indicated on the current September 29, 2017 Flood Insurance Rate Map (FIRM), Community Panel No. 1551661800F. Zone X designations are not subject to the requirements of the Standards of Floodways, Chapter 27, Section 22 of the Hawaii County Code. See Figure 4-13 for the Flood Insurance Rate Map.

This page intentionally left blank.

Path: P:\Projects\Hawaii, County Of (HI)\150440 COH Pahala WWTP\CAD\0-PROJECT\FIGURES
 File Name: 150440-FIG-FIRM Plot Date: March 22, 2018 4:33 PM Cadd User: Richard Sellona



SUBJECT PROPERTY:
ZONE X - AREAS OF MINIMAL FLOODING
BISHOP ESTATES
(KAMEHAMEHA SCHOOLS)
TMK:(3)9-6-002:018



Hawaii County
155166

NATIONAL FLOOD INSURANCE PROGRAM

PANEL 1800F

FIRM
FLOOD INSURANCE RATE MAP
HAWAII COUNTY,
HAWAII

PANEL 1800 OF 1975
 (SEE MAP INDEX FOR FIRM PANEL LAYOUT)

CONTAINS:	NUMBER	PANEL	SUFFIX
COMMUNITY	HAWAII COUNTY	155166	1800 F

Notice to User: The Map Number shown below should be used when placing map orders; the Community Number shown above should be used on insurance applications for the subject community.

MAP NUMBER
1551661800F
MAP REVISED
SEPTEMBER 29, 2017

Federal Emergency Management Agency

LEGEND

SPECIAL FLOOD HAZARD AREAS SUBJECT TO INUNDATION BY THE 1% ANNUAL CHANCE FLOOD

The 1% annual chance flood (100-year flood), also known as the base flood, is the flood that has a 1% chance of being equaled or exceeded in any given year. The Special Flood Hazard Area is the area subject to flooding by the 1% annual chance flood. Areas of Special Flood Hazard include Zones A, AE, AH, AO, AR, A99, V, and VE. The Base Flood Elevation is the water-surface elevation of the 1% annual chance flood.

- ZONE A** No Base Flood Elevations determined.
- ZONE AE** Base Flood Elevations determined.
- ZONE AH** Flood depths of 1 to 3 feet (usually areas of ponding); Base Flood Elevations determined.
- ZONE AO** Flood depths of 1 to 3 feet (usually sheet flow on sloping terrain); average depths determined. For areas of alluvial fan flooding, velocities also determined.
- ZONE AR** Special Flood Hazard Area formerly protected from the 1% annual chance flood by a flood control system that was subsequently decertified. Zone AR indicates that the former flood control system is being restored to provide protection from the 1% annual chance or greater flood.
- ZONE A99** Areas to be protected from 1% annual chance flood event by a Federal flood protection system under construction; no Base Flood Elevations determined.
- ZONE V** Coastal flood zone with velocity hazard (wave action); no Base Flood Elevations determined.
- ZONE VE** Coastal flood zone with velocity hazard (wave action); Base Flood Elevations determined.

FLOODWAY AREAS IN ZONE AE

The floodway is the channel of a stream plus any adjacent floodplain areas that must be kept free of encroachment so that the 1% annual chance flood can be carried without substantial increases in flood heights.

OTHER FLOOD AREAS

- ZONE X** Areas of 0.2% annual chance flood; areas of 1% annual chance flood with average depths of less than 1 foot or with drainage areas less than 1 square mile; and areas protected by levees from 1% annual chance flood.

OTHER AREAS

- ZONE X** Areas determined to be outside the 0.2% annual chance floodplain.
- ZONE D** Areas in which flood hazards are undetermined, but possible.

COASTAL BARRIER RESOURCES SYSTEM (CBRS) AREAS

OTHERWISE PROTECTED AREAS (OPAs)

CBRS areas and OPAs are normally located within or adjacent to Special Flood Hazard Areas.

- 1% annual chance floodplain boundary
- 0.2% annual chance floodplain boundary
- Floodway boundary
- Zone D boundary
- CBRS and OPA boundary
- Boundary dividing Special Flood Hazard Area Zones and boundary dividing Special Flood Hazard Areas of different Base Flood Elevations, flood depths, or flood velocities
- Base Flood Elevation line and value; elevation in feet*
- Base Flood Elevation value where uniform within zone; elevation in feet*

* Referenced to LOCAL MEAN SEA LEVEL

- Cross section line
- Transect line
- Geographic coordinates referenced to the North American Datum of 1983 (NAD 83), Western Hemisphere
- 1000-meter Universal Transverse Mercator grid values, zone 5
- 5000-foot grid ticks: Hawaii State Plane coordinate system, Zone 1 (FIPSZONE = 5101), Transverse Mercator projection
- Bench mark (see explanation in Notes to Users section of this FIRM panel)
- River Mile

THIS IS AN OFFICIAL COPY OF A PORTION OF THE ABOVE REFERENCED FLOOD MAP. IT WAS EXTRACTED USING F-MIT ON-LINE. THIS MAP DOES NO REFLECT CHANGES OR AMENDMENTS WHICH MAY HAVE BEEN MADE SUBSEQUENT TO THE DATE ON THE TITLE BLOCK. FOR THE LATEST PRODUCT INFORMATION ABOUT NATIONAL FLOOD INSURANCE PROGRAM FLOOD MAPS CHECK THE FEMA FLOOD MAP STORE AT WWW.MSC.FEMA.GOV.



SCALE: 1"=2,000'
 JOB NO: 150440

PAHALA WASTEWATER TREATMENT PLANT
FLOOD INSURANCE RATE MAP

FIGURE
4-13

4.6.4.4 Stormwater Quantity

The increase in peak flow and runoff volume is a function of the increase in impervious areas associated with the proposed improvements.

All exposed (not enclosed) treatment processes will be sized to include free-board depth to accommodate the 24-hour, 100-year storm event. Thus, no stormwater runoff from these areas is anticipated.

A drainage system will be designed to address stormwater surface run-off caused by impervious portions of the WWTP development. Per the Hawaii County Code, Chapter 27, Section 20, the site drainage plan shall accommodate the run-off caused by the proposed development, within the site boundaries, for a one-hour, ten-year storm event. The pre-development runoff (10-year, 1-hour storm) is approximately 23 cubic feet per second (cfs). The post-development runoff is approximated at 24.5 cfs, which is a net increase of 1.5 cfs.

To ensure that there is no adverse impact on adjacent or downstream properties due to post-development flows, an on-site drainage system will collect runoff via grated inlets or swales. These flows will be conveyed to on-site drainage detention systems, such as subsurface linear infiltration or depressed detention basins, to detain flows and volumes to their pre-development condition. Furthermore, landscape buffers with dirt berms will be constructed around most of the perimeter of the property acting as secondary containment in the event of a large storm event.

A complete analysis of the pre and post development drainage condition will be completed during the design phase.

4.6.4.5 Stormwater Quality

The quality of stormwater leaving the site is also a concern. Stormwater quality degrades with development and increased impervious surfaces, because various pollutants are introduced into the stormwater runoff.

The first half-inch of runoff during a storm is referred to as the Water Quality Volume (WQV) or the “first-flush” volume. This portion of the runoff from a storm contains measurably more suspended solids plus other contaminants per cubic foot than would be expected in runoff occurring later in the storm.

To mitigate the quality of runoff, the drainage system will incorporate permanent Best Management Practices (BMP's). Recommended permanent BMP include scheduled good-housekeeping, which will reduce litter and other constituents from being washed into the storm drain system, and detention basins and underground infiltration facilities that prevent the release of sediment and other pollutants to downstream waterways or adjacent properties. A full assessment of all available BMP's to optimize water quality will be provided during design of the project.

4.6.5 Electrical Systems

It will be necessary to bring electrical power to the WWTP site. It is anticipated that Hawaii Electric Light Company (HELCO) will bring overhead power lines to the site and supply 480-volt, 3 phase power to the WWTP via a pole-mounted transformer to a service panel with a meter.

The floating surface aerators will consume the majority of the electricity supplied to the site. An electrical room will house the electrical gear, plant control equipment and the chlorination system. Exterior lighting at the site will be limited to manually switched lights at the entrance to the electrical building and at the headworks area.

A standby power system will be provided in the form of a pad-mounted diesel generator and above-ground fuel tank with capacity to support three consecutive days of operation. In addition, the

electrical service panel will be equipped with a manual transfer switch and generator receptacle to allow connection of a trailer-mounted generator in the event of emergency generator failure during an extended power outage.

4.6.6 Telemetry Systems

A land-line telephone telemetry system with auto-dialer will be provided to provide Hilo-based operation staff of alarm conditions and key operational parameters at the WWTP. Additionally, a cell phone will be available for backup.


4.6.7 Operations Building

An operations building will be constructed to include the electrical room, chlorinator room, restroom, and maintenance/storage room, as shown in Figure 4-14.

4.6.8 Site Fencing

The entire WWTP site, including the treatment systems and the land application system, will be fenced (6-foot high chain link) and posted to prevent public access.

Path: P:\Projects\Hawaii, County Of (HI)\150440 COH Pahala WWTP\CAD\0-PROJECT\FIGURES
File Name: 150440-FIG-OpBldg Plot Date: June 12, 2018 2:56 PM Cadd User: Richard Sellona



SCALE: 3/16" = 1'-0"
JOB NO: 150440

PAHALA WASTEWATER TREATMENT PLANT
OPERATIONS BUILDING PRELIMINARY FLOOR PLAN

FIGURE
4-14

Section 5

Preliminary Design of Improvements

The following is a summary of the preliminary design for the proposed Pahala WWTP.

5.1 Site Plan


The existing parcel is an active macadamia nut tree orchard. The prevailing grade is in the north to south direction at 5 to 10 percent slope. Approximately 14.9 acres of the land will be cleared for the construction of the proposed facility. Figure 5-1 presents a preliminary site plan for the WWTP.

5.2 Process Schematic

Figure 5-2 presents the recommended facilities process schematic.

This page intentionally left blank.

Path: P:\Projects\Hawaii, County Of (HI)\150440 COH Pahala WWTP\CAD\0-PROJECT\FIGURES
 File Name: 150440-FIG-PreliminarySitePlan_WithAerial_14.9acre_FullBuildAlternative Plot Date: June 18, 2018 1:46 PM Cadd User: Richard Sellona



NOTE:
 TOPOGRAPHICAL CONTOURS ARE APPROXIMATE
 AND BASED ON PAHALA USGS TOPO QUADRANGLE.




SCALE: 1" = 200'
 JOB NO: 150440

PAHALA WASTEWATER TREATMENT PLANT
 PRELIMINARY SITE PLAN

FIGURE
 5-1

Path: P:\Projects\Hawaii, County Of (HI)\150440 COH Pahala WWTP\CAD\0-PROJECT\FIGURES
 File Name: 150440-FIG-LandAppSys_Schem Plot Date: May 22, 2018 5:26 PM Cadd User: Richard Sellona



SCALE: NONE
 JOB NO: 150440

PAHALA WASTEWATER TREATMENT PLANT
 RECOMMENDED FACILITIES PROCESS SCHEMATIC

FIGURE
 5-2

5.3 Design Criteria

Table 5-1 provides preliminary design criteria.

Table 5-1. Preliminary Design Criteria	
Description	Value
Influent flows:	
• Average dry weather	190,000 gpd
• Peak day wet weather	662,000 gpd
• Peak hour wet weather	630 gpm
Influent characteristics	
• BOD ₅	300 mg/L
• TSS	300 mg/L
Odor control – granular activated carbon	
• Airflow rate	500 cfm
• H ₂ S Inlet concentration	1-10 ppm
• H ₂ S removal efficiency	99%
• Media type	High-capacity carbon
• Vessel diameter	3 feet
• Vessel height	6 feet
• Minimum carbon quantity	570 lbs
• Minimum bed depth	3 feet
• Fan motor	2 hp
• Nominal inlet size	8 inches
Mechanical screens	
• Number of units	2
• Type	In-channel cylindrical
• Screen opening size	0.25 inch (6 mm)
• Maximum flow rate capacity	Greater than 625 gpm each
• Screening washing	Integral
• Screening compaction	Integral
• Screening wash water flow	20 gpm
• Screening wash water pressure	50 psi
Bypass screen	
• Type	Manually-cleaned bar rack
• Bar spacing	1 inch
• Rake	Interlocking with bars
Screenings receptacle	

Table 5-1. Preliminary Design Criteria continued	
• Type	55-gallon drum or bags
• Screenings volume per million gallons treated	5 ft ³ /Mgal
• Estimated screenings quantity	1 ft ³ /day
• Disposal frequency	1/week
Influent flow metering	
• Type	Parshall flume
• Maximum flow capacity	Greater than 630 gpm
• Minimum straight upstream channel section	20 times the throat width
Influent flow sampling	
Refrigerated automatic composite sampler	
Lagoon cells	
• Number of cells	4
• Maximum lagoon temperature	25°C
• Minimum lagoon temperature	20°C
• Freeboard	3 feet
• Working water depth	15 feet
• Allowance for sludge	3 feet
• Total water depth	18 feet
• Side slope	3(H) : 1(V)
• Working volume of lagoon 1 to 3	0.80 Mgal
• Working volume of lagoon 4	1.60 Mgal
Aerators	
• Type	Floating mechanical surface aerators
• Cell 1 aerators	30 hp (2 at 15 hp)
• Cell 2 aerator	15 hp
• Cell 3 aerator	10 hp
• Cell 4 aerator	5 hp aspirator style, floating ball cover for algae control
Constructed Wetland	
• Water temperature	25 degrees C
• Aerated lagoon effluent nitrate-N concentration	19 mg/l
• Aerated lagoon effluent ammonia-N concentration	1 mg/l
• Constructed wetland effluent total N concentration	15.3 mg/l
• Total constructed wetland surface area	0.25 acres
• Flow path length	50 feet
• Hydraulic application width	200 feet
• Media depth	24 inches
• Media type	Medium gravel, D ₁₀ = ¾ inch

Table 5-1. Preliminary Design Criteria continued	
• Media porosity	38 percent
• Percolation prevention system	60 mil high density polyethylene (HDPE) liner
• Vegetation	Native Hawaiian reeds and/or rushes, species to be determined
Disinfection system	
• Type	Chlorine
• Form	Calcium hypochlorite tablets
• Design chlorine dose	10 mg/L
• Chlorine contact time	15 minutes minimum
Effluent flow metering	
• Type	Magnetic
Effluent sampler	
• Type	Refrigerated automatic composite
Effluent quality	
• BOD ₅	Less than 30 mg/L monthly average Less than 60 mg/L peak
• TSS	Less than 30 mg/L monthly average Less than 60 mg/L peak
Effluent management system	
• Type	Slow-rate land application groves
• Number	4
• Minimum depth	5 feet
• Design percolation rate	0.0095 inches per minute
• Design application rate	8 percent of percolation rate
• Distribution system	Gated pipe
• Stormwater containment	100-year, 24-hour storm event
• Vegetation	Native Hawaiian trees
Stormwater site management	10-year, 1-hour storm

5.4 Environmental Benefits

A well-designed and managed land treatment system limits wastewater application to rates to minimize adverse impact to groundwater quality. The deep percolate from the SR land treatment system is expected to contain less than 1 mg/L of BOD₅ and TSS. While the State of Hawaii has not adopted formal groundwater quality standards, the drinking water standard for nitrate (10 mg/L as N) in the annual average deep percolate below the land treatment system was used as a performance target to design the land treatment site. Phosphorus adsorption is excellent in SR land treatment systems, and 99 percent or greater phosphorus removal is anticipated. Table 5-2 compares the current loads to the environment via the LCCs and the loads to the environment after the proposed project is implemented via the deep percolate from the land treatment system. Figure



5-3 provides a graphical representation of the environmental benefits of the proposed project compared to the status quo.

Table 5-2. Environmental Benefits of Proposed Project			
Parameter	Current Annual Load to Environment via LCCs	Annual Load to Environment via Proposed Land Treatment System Deep Percolate	Reduction
BOD ₅	174,000 lbs./year	600 lbs./year	>99%
TSS	174,000 lbs./year	600 lbs./year	>99%
Nitrogen	23,000 lbs./year	4,100 lbs./year	83%
Phosphorus	4,000 lbs./year	40 lbs./year	>99%




Figure 5-3. Environmental Benefits of Proposed Project

5.5 Cost Estimates

An order of magnitude probable construction is summarized in Table 5-3. The estimate includes a 25 percent estimating contingency. The detailed cost estimate is included as Appendix A.

Description	Estimated Construction Cost
Electrical and instrumentation	\$1,976,000
Headworks	\$906,000
Odor Control	\$412,000
Lagoons	\$2,222,000
Constructed Wetland	\$611,000
Land Application	\$925,000
On-site improvements	\$6,325,000
Off-site improvements	\$1,223,000
Total Estimated Construction Cost	\$14,600,000

5.6 Future Expansion

5.6.1 Full Buildout Flows

Full buildout wastewater flow projections were developed using the Draft Ka'u Community Development Plan (March 2015) and the CCH's current (2017) wastewater standards. Table 5-4 summarizes the projected full buildout flows for the community, and Figure 2-1 shows the WWTP full buildout service area.

Description	Value	Peaking Factor
Average dry weather flow	360,000 gallons per day	1.0
Peak day wet weather flow	1,260,000 gallons per day	3.5
Peak hour wet weather flow	1,200 gallons per minute	4.8

5.6.2 Improvements

To accommodate the flow increase anticipated from the full buildout of the Pahala wastewater collection system, the WWTP will require facility upgrades. The recommended upgrades include headworks and odor control expansion within the 14.9-acre site.

Additionally, the lagoon system will require modifications. Lagoon 1 will be converted to a complete mix aerated lagoon environment to accommodate wastewater treatment needs. In a complete mix aerated lagoon, sufficient mixing energy is provided to maintain the lagoon solids in suspension always. A completely mixed aerated lagoon system performs as an activated sludge process without solids recycle. The higher mixing energy, as compared to a partial mix lagoon, creates greater

opportunity for contact between the naturally-occurring micro-organisms in the lagoon and dissolved organic matter. As a result, complete mix lagoons provide greater levels of treatment within a smaller volume than partial mix lagoons. However, facilities must be provided downstream of complete mixed lagoons to allow removal of settleable solids from the water column. To provide a place for solids settling, lagoons 2 through 4 will continue to act as partial mix aerated lagoons downstream of the complete mix lagoon 1. Lagoon 4 will require no aeration and will continue to be covered to deprive algae of sunlight and allow suspended solids to settle out of the system effluent.

Utilizing this lagoon system approach, the Pahala WWTP will require modifications at full buildout flows, but is not anticipated to expand beyond the initial build 14.9 acres.

Section 6

Implementation

Table 6-1 provides the implementation schedule for the WWTP. The LCCs will be closed following connection of the existing sewer system to the WWTP.

Table 6-1. Implementation Schedule	
Description	Milestone
Complete design of WWTP	September 18, 2019
Complete construction of WWTP	May 20, 2021
Connect existing collection system to WWTP	June 30, 2021

This page intentionally left blank.

Section 7

Alternative Treatment Options Evaluation

Several other treatment alternatives were considered for the Pahala WWTP, as summarized below.

7.1 Option Descriptions

7.1.1 Option 1: Aerated Lagoons/Constructed Wetland/Land Application

Option 1 consists of an aerated lagoon treatment system with a constructed wetland and disinfection, followed by land application for effluent management, as described previously throughout this report. Figure 7-1 is a schematic diagram for Option 1.



Figure 7-1. Option 1 Schematic Diagram

7.1.2 Option 2: R-1 Treatment/Land Application

Option 2 consists of constructing a membrane bioreactor (MBR) or an activated sludge treatment process followed by cloth media filtration, followed by UV disinfection, to produce recycled water that meets DOH R-1 recycled water criteria. R-1 recycled water is effluent that has undergone oxidation, filtration, and disinfection. R-1 is considered the highest grade of recycled water and can be used for irrigation of golf courses, parks, schools, and all types of agricultural crops. The R-1 treatment system would be followed by land application as per Option 1. Figure 7-2 is a schematic diagram for Option 2.




Figure 7-2. Option 2 Schematic Diagram

7.1.3 Option 3: R-1 Treatment/Seasonal Water Recycling

Option 3 consists of a treatment system similar to Option 2 to produce R-1 recycled water. The recycled water would be used to irrigate nearby macadamia nut orchards. Figure 7-3 provides a schematic diagram of Option 3.




Figure 7-3. Option 3 Schematic Diagram

A water recycling analysis was prepared to assess the potential seasonal demand for recycled water produced by the WWTP. Figure 7-4 is an irrigation demand assessment for the Pahala area based on published climate data. The graph shows precipitation, estimated evapotranspiration, and the irrigation demand for each month of the year. As shown in the figure, irrigation is typically needed from April through September, reaching a peak demand in June. The graph shows that no irrigation is typically needed between October and March, because precipitation exceeds evaporation during those months.




Figure 7-4. Irrigation Demand Assessment

The potential demand for recycled water produced by the Pahala WWTP was assessed, as shown in Figure 7-5. The WWTP could potentially provide irrigation water for approximately 62 acres, based on the peak month irrigation demand in June. During June, all the recycled water produced by the WWTP would be used on the 62 acres. During all other months the supply of recycled water will typically exceed the demand, and the excess water would be land applied on the WWTP property as per the previous alternatives.




Figure 7-5. Option 3 Recycled Water Demand Assessment

The Pahala climate makes it possible to only recycle only about 25 percent of the annual flow in this scenario, due to the long wet season and relatively low evapotranspiration rate during the dry season. This is in stark contrast to the Kailua-Kona area on the leeward side of the island, where the climate will allow approximately 88 percent of the recycled water produced at the Kealakehe WWTP

throughout the year to be recycled. Figure 7-6 provides a comparison of the irrigation demand in Pahala with the irrigation demand at Kealakehe.




Figure 7-6. Comparison of Irrigation Demands at Pahala and Kealakehe

7.1.4 Option 4: R-1 Treatment and Storage for 100% Water Recycling

Option 4 adds a seasonal storage reservoir, as shown schematically in Figure 7-7.




Figure 7-7. Option 4 Schematic Diagram

Implementation of a seasonal storage reservoir would make it possible to recycle 100 percent of the R-1 water produced by the Pahala WWTP in a typical year. The seasonal storage reservoir would make it possible to save recycled water produced during the wet season for use during the dry season. An annual water balance was prepared to assess the seasonal storage reservoir needs for the Pahala WWTP. Figure 7-8 provides a summary of the evaluation, and shows recycled water supply, use, and storage throughout a typical year. As shown in the graph, peak storage of approximately 40 million gallons (Mgal) would occur during April, and by August the storage reservoir would be dry and ready for another wet season. Under this scenario it would be possible to irrigate approximately 253 acres of macadamia nut trees. The lined, 20-foot-deep storage reservoir would have a water surface area of approximately 7 acres.

Storage of recycled water is not without its challenges. Recycled water contains nutrients that allow algae to grow. The algae can cause odors if stagnant water conditions are allowed to develop. Recycled water that is stored in open reservoirs must often be re-treated to improve the water quality characteristics. Recycled water reservoirs can be equipped with mixers to prevent stagnant water conditions, and/or be equipped with floating covers to block the sunlight that fosters algal growth.




Figure 7-8. Seasonal Storage Reservoir Analysis

Implementation of a seasonal storage reservoir and recycling program would not eliminate the need for a land application system at the WWTP, as described previously. HAR 11-62 requires a disposal system for all recycled water system, to provide a means for disposal of water that does not meet R-1 standards or disposal of excess water should the seasonal storage reservoir capacity be exceeded during an exceptionally wet year.

7.1.5 Option 5: Maximum Practical Treatment

Option 5 consist of implementing advanced wastewater treatment processes that represent maximum practical treatment. The option is illustrated schematically in Figure 7-9. The process treatment train consists of a 5-stage Bardenpho activated sludge treatment process, followed by chemical addition and denitrifying filters to reliably reduce total nitrogen to less than 4 mg/L and total phosphorus to less than 0.1 mg/L. The treatment processes would be followed by a disinfection process to create R-1 recycled water. The recycled water produced would be used to irrigate macadamia nut trees as per Option 3. A seasonal storage reservoir could also be implemented at additional cost. A land application system would be required as per the previous Options.




Figure 7-9. Option 5 Schematic Diagram

7.2 Cost Comparisons

Planning-level cost estimates were prepared for the five options, as described below.

7.2.1 Capital Costs

Table 7-1 summarizes the capital costs associated with the options described above. Additional detail can be found in Appendix A. The capital costs shown in the table do not include costs associated with collection system improvements or closure of the existing LCCs.

Table 7-1. Summary of Capital Cost Estimates		
Option	Name	Estimated Capital Cost
1	Aerated lagoons/constructed wetland/land application	\$14.6 million
2	R-1 treatment/land application	\$18.4 million
3	R-1 treatment/seasonal water recycling	\$20.2 million
4	R-1 treatment and storage for 100% water recycling	\$30.4 million
5	Maximum practical treatment	\$26.0 million

Comparison of options 1 and 2 shows that providing R-1 treatment instead of the aerated lagoon and wetland natural treatment system will increase the capital cost by approximately \$3.8 million. Option 3 shows that addition of water recycling to reuse approximately 25 percent of the annual flow would add an additional \$1.8 million in capital costs. Option 4 shows that constructing a seasonal storage reservoir to recycle 100 percent of the flow would add an additional \$10 million in capital costs. Comparison of options 3 and 5 shows that providing maximum practical treatment instead of normal R-1 treatment would add \$5.8 million in capital costs.

7.2.2 Operation and Maintenance Costs

Operation and maintenance (O&M) costs include labor, electricity, chemicals, spare parts, sludge management, and other costs required to operate and maintain the facility. Table 7-2 provides a

summary of the O&M cost estimates developed for the options. Additional details can be found in Appendix A.

Option	Name	Estimated Annual O&M Cost
1	Aerated lagoons/constructed wetland/land application	\$236,000
2	R-1 treatment/land application	\$1,052,000
3	R-1 treatment/seasonal water recycling	\$1,055,000
4	R-1 treatment and storage for 100% water recycling	\$1,063,000
5	Maximum practical treatment	\$1,421,000

As shown in the table, option 1 incurs significantly lower O&M costs than the other options. The significant cost differential is due to the simple aerated lagoon natural treatment system that requires less labor, electricity, chemical, and maintenance than the other options.

7.2.3 Recycled Water Sale Proceeds

Options 3, 4, and 5 will produce a marketable product in the form of R-1 recycled water that could be sold to users for irrigation purposes. The value of recycled water is a function of the value of the water that it replaces. In general, recycled water is sold to users at a fraction of the price of the water that is being replaced to provide a financial incentive to use the product. The typical recycled water price is 25 percent to 90 percent of the water it replaces.

The Pahala WWTP will be located at elevation 750 feet MSL. The cost to pump groundwater from the basal lens to the ground surface at the WWTP is approximately \$1,078 per million gallons. Table 7-3 provides a summary of a recycled water sales assessment of each option, assuming the recycled water is sold for 90 percent of the cost of the irrigation water it would replace. Additional detail is provided in Appendix A.

Option	Name	Annual Volume Recycled (Mgal)	Maximum Annual Sales Proceeds
1	Aerated lagoons/constructed wetland/land application	0	\$0
2	R-1 treatment/land application	0	\$0
3	R-1 treatment/seasonal water recycling	17	\$17,000
4	R-1 treatment and storage for 100% water recycling	70	\$68,000
5	Maximum practical treatment	17	\$17,000

7.2.4 Life-Cycle Costs

Life-cycle costs represent the total costs to the community to construct and operate the wastewater treatment system over a 30-year period. The life-cycle cost evaluation includes capital and O&M costs, and recycled water sales proceeds as described above. In addition, equipment replacement allowances are included after 20-years of operation. The life-cycle cost evaluation includes an

inflationary factor to account for long-term changes in the value of money. The life-cycle costs are expressed as the Net Present Value (NPV). The NPV represents the amount of money that the County would need to set aside now in an interest-bearing account to cover all of the costs over the defined life-cycle. Table 7-4 provide a summary of the life-cycle cost evaluation. Additional detail can be found in Appendix A.

Table 7-4. Summary of Life-Cycle Cost Estimates		
Option	Name	Estimated Life-Cycle Cost
1	Aerated lagoons/constructed wetland/land application	\$21.2 million
2	R-1 treatment/land application	\$43.0 million
3	R-1 treatment/seasonal water recycling	\$44.5 million
4	R-1 treatment and storage for 100% water recycling	\$54.0 million
5	Maximum practical treatment	\$59.0 million

As shown in the table, option 1 incurs the lowest life-cycle costs, and the other options would all incur over double to nearly triple the cost over the 30-year life-cycle. The life-cycle cost estimates are shown graphically in Figure 7-10. The operating costs shown in the figure include benefits (i.e., cost reductions) from recycled water sales where applicable.




Figure 7-10. Life-Cycle Costs of Options

As shown in the graph, the operating cost differential between option 1 and the other options is the leading contributor to the lower life-cycle cost of option 1. The major operating cost differences are discussed below.

7.3 Non-Economic Discussion

The options are discussed on a non-economic basis below.

7.3.1 Labor Requirements

The Pahala WWTP will be operated by the COH DEM, Wastewater Division that is based in Hilo. The Hilo-based WWTP operators will regularly visit to facility to check the system status, make operational adjustments, and draw samples for required laboratory testing. In addition, maintenance personnel will visit the WWTP as needed to conduct equipment and electrical system repairs.

A major difference between option 1 and the other options is the frequency of routine operator visits required, and the number of personnel routinely required. Option 1 will require a single operator to normally visit the site once per week. The other options will require daily operator visits to conduct sampling that is required for R-1 compliance. In addition, options 2 through 5 consist of mechanical treatment technology that required more operator attention than option 1. Table 7-5 compares the operational labor differences for the options, as expressed as full-time equivalents (FTEs).

Option	Name	Estimated Operational Labor Requirement (FTEs)
1	Aerated lagoons/constructed wetland/land application	0.3
2	R-1 treatment/land application	3.7
3	R-1 treatment/seasonal water recycling	3.7
4	R-1 treatment and storage for 100% water recycling	3.7
5	Maximum practical treatment	5.6

7.3.2 Operational Complexity

HAR 11-61 establishes operator certification requirements for WWTPs. The DOH requires that certified operators operate municipal WWTPs. The larger and/or more complex the wastewater treatment process, the higher grade of operator required at the facility. Options 1 through 5 were evaluated for operator certification requirements based on the criteria established in HAR 11-61. Table 7-6 summarizes the results of the evaluation. As shown in the table, option 1 would require a Grade I operator, while the other options would require a Grade IV operator (the highest grade). The higher requirements for options 2 through 5 are due to the complexity of the treatment processes compared to option 1. In general, the County has difficulty attracting and retaining Grade IV operators.

Option	Name	Operator Certification Level Requirement
1	Aerated lagoons/constructed wetland/land application	I
2	R-1 treatment/land application	IV
3	R-1 treatment/seasonal water recycling	IV
4	R-1 treatment and storage for 100% water recycling	IV
5	Maximum practical treatment	IV

7.3.3 Energy Consumption

Figure 7-11 provides a comparison of the electrical energy requirements of the five options. As shown in the graph, option 1 will require significantly less electrical energy to operate, due to the use of natural treatment systems (aerated lagoons) instead of mechanical treatment processes that require more aeration and process pumping.




Figure 7-11. Comparison of Electrical Energy Requirements

7.3.4 Sludge Management

Sludge management for Option 1 is significantly different than the other options. The partial-mix aerated lagoon treatment system allows wastewater solids to accumulate at the bottom of the lagoon, forming a sludge blanket that slowly anaerobically digests. Sludge removal is infrequent, typically on the order once every 15 to 20 years. The resulting solids are well-digested and inoffensive due to the long retention time in the lagoons.

Options 2 through 5 would require an aerobic digester to stabilize and store waste solids from the activated sludge treatment process. The solids would need to be dewatered and trucked to a landfill on a weekly basis.

7.4 Living Machine®

Living Machine® technology was suggested during community outreach meetings. Living Machine® is a proprietary technology by Worrell Water Technologies that incorporates aerated tanks planted with vegetation to provide an attractive wastewater treatment process. In colder climates the aerated tanks are housed in a greenhouse for protection. In addition, subsurface flow wetlands with continuous and/or batch flow can be included in the process to provide desired treatment.

The Living Machine® technology has been implemented in “green” buildings like the San Francisco Public Utilities Commission building, the Port of Portland Headquarters, and others. Review of the company’s website did not reveal any municipal projects completed on the scale of what would be needed for Pahala. Therefore, the technology is considered to be not feasible.

It should be noted that the proposed non-proprietary treatment system (aerated lagoons and subsurface flow wetland) uses essentially the same natural treatment processes as the Living Machine®, but on a municipal scale.

7.5 Septic Tank Alternatives

A previous assessment recommended installation of a community septic tank and repurposing one of the existing LCCs to serve as a seepage pit (SSFM, July 2007), in accordance with Alternative 1 proposed to the community by the County in 2004 (County of Hawaii, November 5, 2004). This and other options that have been raised during the community outreach process that incorporate septic tank technology are discussed below.

7.5.1 Community Septic Tank

The effectiveness of a septic tank is directly related to the amount of hydraulic detention time provided by the tank volume. The previous study (SSFM, July 2007) suggested a 24-hour detention time would be adequate. Applying the current flow projections for the project indicate a 190,000-gallon tank would be appropriate if this criterion is used. However, for large community septic tanks it has been found that longer detention times are needed to optimize treatment performance, avoid the need for frequent septage pumping, and to account for peak flow rates that are developed by community wastewater collection systems. Applying appropriate design criteria (Crites and Tchobanoglous, 1998), to the project results in the need for an 800,000-gallon tank, which would require pumping on a 3-year interval. The area required for an appropriately-sized community septic tank would be approximately $\frac{1}{4}$ acre.

The use of a community septic tank would require the DOH to issue a variance to HAR 11-62-23.1, which requires WWTPs with design capacities greater than 100,000 gallons per day to produce effluent containing less than 30 mg/L of both BOD₅ and TSS – septic tanks are not able to produce effluent of this quality. A secondary treatment process is needed to comply with the effluent quality requirements contained in the DOH regulations. The County would need to reapply for the variance every 5-years, and if not renewed then secondary treatment would need to be provided.

Additionally, odors from a community septic tank present a significant concern. A septic tank is an anaerobic treatment process that produces hydrogen sulfide, reduced sulfur compounds, and other odorous gases. Odors emanating from septic tanks at individual residences are typically dispersed to the atmosphere throughout the community via the household plumbing roof vents. A community septic tank would concentrate the community's emissions to a single point source that would require foul air collection and treatment to avoid nuisance odor conditions. A dual-stage scrubber capable of treating approximately 3,600 cubic feet per minute of foul air would be required to avoid nuisance odor conditions. The dual-stage scrubber would consist of a biotrickling filter, followed by a granular activated scrubber.

7.5.2 Converting LCC to Seepage Pit

A previous study (SSFM, July 2007) suggested that the existing LCC located on the County-owned parcel TMK 9-6-002:024 could be converted to a seepage pit that would be regulated by DOH as an injection well. HAR 11-23-07 allows injection wells located mauka of the UIC line that were in existence prior to July 6, 1984 to continue to operate. However, the flow to the wells cannot increase, nor can a new well be constructed. Therefore, the earlier plan to convert the existing LCC to a seepage pit is not feasible for the following reasons:

- Closing LCC No. 2 that is located on private property would not be allowed, as it would increase the flow to LCC No. 1 (converted to a seepage pit that is regulated as an injection well) that is located on County property.

- The capacity, structure, and condition of the existing LCC No. 1 is not known. The LCC could either be a lava tube or a large conventional cesspool. A geotechnical investigation conducted on the site to depths of 30 to 35 feet did not reveal the presence of lava tubes (Masa Fujioka & Associates, January 9, 2007), therefore it is likely a large conventional cesspool. The County attempted to determine the structure and condition of the LCC via closed circuit TV inspection, but could not ascertain either due to technological limitations. It is not known if the LCC could accommodate the flow from the existing service area if LCC No. 2 is closed.
- HAR 11-62-25 requires new and proposed effluent disposal systems to have a backup disposal system capable of handling the peak flow. A second seepage pit cannot be constructed to comply with the regulatory requirement because the site is located mauka of the UIC line. If the existing seepage pit were to fail then a replacement cannot be constructed.
- The Kau Community Development Plan requires the County to provide for eventual construction of sewers throughout the community. Providing sewers for the entire community will increase wastewater flows considerably, as presented in Section 5. Increasing flow to the existing LCC (converted to a seepage pit) would not be allowed. Therefore, the use of the existing LCC as a disposal system could prevent the County from providing the community's desired future wastewater needs.

For these reasons, converting the existing LCC to a seepage pit is considered to be not feasible.

7.5.3 Leachfield Disposal

Leachfields are effluent disposal systems consisting of buried gravel-filled absorption trenches. Significant treatment occurs as septic tank effluent percolates through the soil surrounding the leachfield trenches. Leachfields are an integral part of residential septic systems, and DOH has established trench design criteria applicable to both residential and municipal-scale leachfields. In particular, HAR 11-62-34 requires trenches to be sized based on bottom area only. Application of the DOH criteria to the project yields a need for at least 30 acres of land to satisfy DOH hydraulic loading rate and redundancy requirements. Achieving even distribution of effluent over a leachfield of this size would be challenging at best. Therefore, leachfield disposal for the project is considered to be not feasible.

7.5.4 Conversion to Individual Wastewater Systems

The concept of a community wastewater system could be abandoned and all houses be required to construct individual wastewater systems comprised of a septic tank and leachfield. However, many of the lots in the community are small (less than 10,000 square feet) and significantly improved, making the feasibility of constructing individual wastewater systems on every lot uncertain. HAR 11-62-34 allows construction of seepage pits where there is insufficient land area to install absorption trenches (i.e., a leachfield), but prohibits construction in soils having percolation rates slower than 10 minutes per inch or where rapid percolation through such soils may result in contamination of water-bearing formations. The soils in the community are classified as Puueo-Naalehu complex, 3 to 10 percent slopes in the National Resource Conservation Service soil survey. This soil type consists of approximately 18 inches of extremely cobbly medial silt loam over cobbles and bedrock. This soil profile is too thin for conventional soil absorption trenches, so residents with sufficient space would be required to import fill soil to create elevated mound systems in accordance with HAR 11-62-34 to achieve adequate soil depth. Residents without sufficient space could potentially install seepage pits if suitable subsurface geology could be located. However, previous subsurface investigations in the community (Masa Fujioka & Associates, January 9, 2007, and Geolabs-Hawaii, September 23,

1998) revealed extremely permeable clinker layers and numerous lava tubes, both of which would not meet HAR 11-62-34 requirements for seepage pits. For these reasons, conversion to individual wastewater systems is considered to be not feasible.

Section 8

Alternative Site Evaluation

Nine sites were evaluated as potential locations for the Pahala WWTP. Each site was assessed for twenty-one criteria, in four broad categories: environmental, social and cultural; location and site; land use and availability; and collection system and service area.

8.1 Methodology

The site evaluation was performed according to the following process:

1. Potential sites for the Pahala WWTP were initially identified by the Department of Environmental Management. Additional sites were identified based on feedback from the Pahala community obtained during Community Outreach meetings that took place in December 2017.
2. Four general categories and twenty-one criteria were established and defined for the analysis.
3. Six “fatal flaw” conditions were identified. Sites with a fatal flaw were eliminated from further consideration.
4. Relative weighting factors were established for each category and criteria.
5. Sites were mapped using GIS. Data such as soil type, location of subsurface and surface water, topography, zoning and prevailing wind direction were determined.
6. Each site was evaluated and scored for the twenty-one criteria.
7. A weighted ranking was determined for each site, based on the weighting factors established in Step 4.
8. A preferred site was identified, based on the weighted high score.






8.2 Site Locations


Ownership, location, and proximity to the existing LCCs for all siting alternatives considered is illustrated in Figure 8-1.

This page intentionally left blank.

ID No.	Land Owner	TMK
1	County of Hawaii	9-6-002:024
2	PMK Capital Partners LLC	9-6-002:016
3	Hawaii Electric	9-6-002:043
4	Mauna Loa Macadamia Orchards LP	9-6-002:048
5	State of Hawaii	9-6-002:005
6	State of Hawaii	9-6-002:013
7	Kamehameha Schools	9-6-002:018
8	Kamehameha Schools	9-6-002:021
9	Kamehameha Schools	9-6-002:049

LEGEND

-  Streams
-  Non-Potable Water Well
-  Potable Water Well
-  Existing Large Capacity Cesspool (LCC)
-  Pahala WWTP Alternative Sites



SCALE AS SHOWN
JOB NO.: 150440

PAHALA WASTEWATER TREATMENT PLANT
Pahala Site Alternatives

FIGURE
8-1

8.3 Criteria

The criteria used for the analysis are presented for each of four categories in Tables 8-1, 8-2, 8-3 and 8-4. A score was assigned to each criterion based on definitions included in the tables. A score of five represents a preferred or positive condition, and a score of one a less preferred or negative condition. A score of zero indicates a fatal flaw; six fatal flaw conditions were identified during the analysis are identified in the corresponding table.

Table 8-1 outlines the environmental, social, and cultural criteria considered in the analysis.

Table 8-1. Environmental, Social and Cultural Criteria						
Criteria	Scoring and Definitions					
	5	4	3	2	1	0 = Fatal Flaw
Presence of or proximity to archaeological/cultural sites	No known or suspected sites	Confirmed or suspected sites and mitigatable	No information available	Confirmed or suspected sites and mitigation ability unknown	Confirmed sites and mitigation ability unknown	Confirmed sites and unmitigatable
Proximity of treatment units to existing occupied buildings	More than 1000 ft. from any occupied building		Between 50 and 1000 ft. from non-school building	Between 50 and 1000 ft. of school	Less than 50 ft from any occupied building	
Prevailing wind direction	Site is downwind of most of the community		Site is central		Site is upwind of most of the community	
Biology	Endangered or threatened species not present		Presence of endangered or threatened species unknown		Endangered or threatened species known to be present	Endangered or threatened species known to be present and unmitigatable
Visual impact	Natural visual mitigation (hill, berm, vegetation, remoteness) exists		Visible location, mitigatable with trees or other engineered buffers		Visible location, unmitigatable	
Contamination from prior land use	No suspected industry-related contamination issues		Presence of contamination unknown		Suspected or confirmed contamination issues	
Previously disturbed or developed	Yes		Partial		No previous development or disturbance	

The circumstance where a cultural or historical site is known to exist within the treatment facility footprint and mitigation to relocate, protect, or preserve that site is not possible, was identified as a fatal flaw condition.

From an environmental perspective, the presence of endangered or threatened species was considered negative. A site previously disturbed or developed was viewed as positive, unless contamination from a previous land use was suspected.

Considerations specific to social impact include proximity to occupied buildings (including residences, school, commercial establishments and others), prevailing wind direction, and visual impact.

Table 8-2 outlines the location and site characteristics considered in the analysis.

Table 8-2. Location and Site Characteristics						
Criteria	Scoring and Definitions					
	5	4	3	2	1	0 = Fatal Flaw
Parcel size	More than 14.9 acres					Less than 14.9 acres
Soils type	Good soil and in sufficient amounts in area of parcel useable for disposal		Good soil but over limited area and disposal modification required		Marginal soil in area of parcel useable for disposal	No soil in area of parcel useable for disposal
Topography	Gentle slopes (less than 8%)		Moderate slopes (8% - 18%) or localized high/low points		Steep slopes (18% - 20%)	Extreme slopes (greater than 20%)
Proximity to water well	Outside of both 1000 ft. radius and upgradient influence zone of any well		Outside of 1000 ft. but suspected within upgradient influence zone of non-potable well		Within 1000 ft. or within upgradient influence zone of non-potable well	Within 1000 ft. or within upgradient influence zone of potable well
Presence of lava tubes	None		Possible or unknown		Known	
Proximity to surface water, intermittent stream or coast line	Treatment and disposal more than 500 ft. away		Treatment and disposal between 50 to 500 ft.		Treatment and disposal less than 50 ft. away	
Flood control / drainage	No risk of flooding		Flood risk unknown		Prone to flooding or within flood zone	
Vehicle access	Vehicle access currently exists		Existing easement, but new road or significant road upgrades required in or via county/private right if way	Existing easement, but new road or significant road upgrades required in or via state right-of-way	No current vehicle access or easement, access legally restricted, or significant obstruction to access	
Power and potable water availability	Utilities currently available at property line and within 400 ft. of site, no new easement required, no known significant obstructions (i.e. - culverts, streams, cultural sites)		Utilities available within 400 yds. of property or unknown		Potable water and/or power not currently available within 400 yds. of property and/or significant obstruction to utility construction	

Three fatal flaw conditions were identified for the location and site characteristics category in Table 8-2:

- Sites less than 14.9 acres in size, which is the least amount of land needed for treatment, disposal, and future growth.
- Average slopes greater than 20 percent, which significantly increase the cost of construction and limit design options.
- Location within a 1000-foot radius surrounding a potable water well, which is prohibited by HAR 11-62 for the protection of drinking water in the State of Hawaii.

Table 8-3 outlines the collection system and service area characteristics considered in the analysis.

Table 8-3. Collection System and Service Area Criteria					
Criteria	Scoring and Definitions				
	5	4	3	2	1
Distance from LCC collection area	Parcel is adjacent to existing LCC or less than 0.25 miles away	Parcel is 0.25-0.5 mile away from existing LCC	Parcel is 0.5-1.0 miles away from existing LCC	Parcel is 1.0 - 1.5 miles away from existing LCC	Parcel is more than 1.5 miles away from existing LCC
Gravity flow possible or pumping required	Gravity flow possible				Pumping required for wastewater transmission from collection area to site
Number of properties newly accessible	Commercial areas become accessible		Additional individual residential properties become accessible outside of LCC service area		No additional properties become accessible

A site location requiring large transmission distances of more than two miles are less preferable due to both initial capital cost and future operations and maintenance requirements. Similarly, sites where wastewater can flow via gravity from the collection area are preferable to those requiring a pump station.

Newly accessible refers to properties within the service area that are not currently connected to the LCC, but will become accessible to the County-owned sewer system when the collection lines are relocated into the roadways fronting the property. Hawaii County Code requires connection of these properties once the new collection system is constructed, and their individual wastewater systems (cesspools or septic tanks) properly removed from service. All individual cesspools in the State of Hawaii must be converted or closed by the year 2050.

Table 8-4 outlines the land use and availability characteristics considered in the analysis.

Table 8-4. Land Use and Availability Criteria					
Criteria	Scoring and Definitions				
	5	4	3	2	1
Current zoning and land use	WWTP currently permitted in zoning without Special Permit		WWTP possible onsite Special Permit required		WWTP not recommended on site
Land availability	Owner willing and able to sell or land currently government (state, county) owned	Subdivision required or friendly condemnation required	Difficult or lengthy approval process expected or owner willingness to sell unknown	Owner unwilling to sell or unfriendly condemnation of land required (private corporate owner)	Owner unwilling to sell or unfriendly condemnation required (private family owner)

Although public facilities are permitted in any zoning in the County of Hawaii, construction of a wastewater treatment facility requires a Special Permit within some zones. No fatal flaws were identified for the land use and availability category.

8.4 Criteria Weighting Factors

To consider the relative importance to the categories and criteria, each was assigned a weighting factor for the analysis. Weighting allows for appropriate consideration of all factors - both the technical and non-technical - associated with siting. Relative weighting is summarized in Table 8-5.

Table 8-5. Relative Weighting Factors			
Category	Category Weight	Criteria	Criteria Weight
Environmental, social and cultural	35%	Presence of and/or proximity to archaeological/cultural sites	25%
		Proximity of treatment units to existing occupied buildings	25%
		Prevailing wind direction	25%
		Biology	10%
		Visual impact	5%
		Contamination from prior land use	5%
		Previously disturbed or developed	5%
			100%
Location and site characteristics	35%	Parcel size	25%
		Soils type	25%
		Topography	15%
		Proximity to water well	10%
		Presence of lava tubes	8%
		Proximity to surface water, intermittent stream or coast line	6%
		Flood control / drainage	5%
		Existing vehicle access	3%
		Power and potable water availability	3%
			100%
Collection system and service area	20%	Distance from LCC collection area	50%
		Gravity flow possible or pumping required	30%
		Number of properties newly accessible	20%
	100%		
Land use and availability	10%	Current ownership	55%
		Current zoning and land use	45%
	100%		

8.5 Raw Scores

For the nine sites identified in Figure 8-1, raw scores were assigned for each of the twenty-one criteria according to the definitions in Section 8.3. The results are presented in Table 8-6.

Table 8-6. Alternatives Analysis – Raw Scores										
Category	Criteria	Site Raw Score								
		1	2	3	4	5	6	7	8	9
Environmental, social and cultural	Presence of and/or proximity to archaeological/cultural sites	5	1	2	3	3	3	4	3	3
	Proximity of treatment units to existing occupied buildings	3	3	5	5	5	5	5	5	5
	Prevailing wind direction	5	5	5	5	5	5	5	5	5
	Biology	3	3	3	3	3	3	3	3	3
	Visual impact	3	3	3	5	5	5	3	3	3
	Contamination from prior land use	3	1	3	1	3	3	3	3	3
	Previously disturbed or developed	5	5	5	3	3	3	5	5	5
Location and site characteristics	Parcel size ^a	0	5	0	5	5	5	5	5	5
	Soils type	5	1	1	3	5	1	5	5	5
	Topography	3	5	3	5	3	5	3	3	5
	Proximity to water well ^b	0	5	5	3	5	5	5	5	5
	Presence of lava tubes	1	1	3	3	3	3	3	3	3
	Proximity to surface water, intermittent stream or coast line	5	5	5	5	3	5	5	1	5
	Flood control / drainage	3	3	3	3	3	1	3	3	3
	Existing vehicle access	5	5	2	2	2	5	5	5	2
Power and potable water availability	3	3	3	1	1	1	3	3	1	
Collection system and service area	Distance from LCC collection area	5	5	4	3	3	2	5	4	3
	Gravity flow possible or pumping required	5	5	5	5	1	1	5	5	5
	Number of properties newly accessible	3	3	3	3	3	3	3	3	3
Land use and availability	Current zoning and land use	3	3	3	3	3	3	3	3	3
	Current ownership	5	5	3	3	5	5	4	4	4
Raw score totals (maximum possible = 105)		FF	75	FF	72	72	72	85	79	79

^a Fatal flaw condition for Sites 1 and 3.

^b Fatal flaw condition for Site 1.

As indicated in Table 8-6, fatal flaw conditions were identified for Site 1 (due to both parcel size and proximity to a drinking water well) and Site 3 (due to parcel size). These two sites were removed from further analysis.

8.6 Weighted Analysis

The weighted analysis is presented in Table 8-7.

Table 8-7. Alternatives Analysis – Weighted Scoring										
Category	Criteria	Site Weighted Score								
		1	2	3	4	5	6	7	8	9
Environmental, social and cultural	Presence of and/or proximity to archaeological/cultural sites		0.25		0.75	0.75	0.75	1.00	0.75	0.75
	Proximity of treatment units to existing occupied buildings		0.75		1.25	1.25	1.25	1.25	1.25	1.25
	Prevailing wind direction		1.25		1.25	1.25	1.25	1.25	1.25	1.25
	Biology		0.30		0.30	0.30	0.30	0.30	0.30	0.30
	Visual impact		0.15		0.25	0.25	0.25	0.15	0.15	0.15
	Contamination from prior land use		0.05		0.05	0.15	0.15	0.15	0.15	0.15
	Previously disturbed or developed		0.25		0.15	0.15	0.15	0.25	0.25	0.25
Location and site characteristics	Parcel size ^a		1.25		1.25	1.25	1.25	1.25	1.25	1.25
	Soils type		0.25		0.75	1.25	0.25	1.25	1.25	1.25
	Topography		0.75		0.75	0.45	0.75	0.45	0.45	0.75
	Proximity to water well ^b		0.50		0.30	0.50	0.50	0.50	0.50	0.50
	Presence of lava tubes		0.08		0.24	0.24	0.24	0.24	0.24	0.24
	Proximity to surface water, intermittent stream or coast line		0.30		0.30	0.18	0.30	0.30	0.18	0.30
	Flood control / drainage		0.15		0.15	0.15	0.05	0.15	0.15	0.15
	Existing vehicle access		0.15		0.06	0.06	0.15	0.15	0.15	0.06
Power and potable water availability		0.09		0.03	0.03	0.03	0.09	0.09	0.03	
Collection system and service area	Distance from LCC collection area		2.50		1.50	1.50	1.00	2.50	2.00	1.50
	Gravity flow possible or pumping required		1.50		1.50	0.30	0.30	1.50	1.50	1.50
	Number of properties newly accessible		0.60		0.60	0.60	0.60	0.60	0.60	0.60
Land use and availability	Current zoning and land use		1.35		1.35	1.35	1.35	1.35	1.35	1.35
	Current ownership		2.75		1.65	2.75	2.75	2.20	2.20	2.20
Overall weighted totals (maximum possible = 5)		FF	3.61	FF	3.76	3.76	3.46	4.33	4.06	4.10

^a Fatal flaw condition for Sites 1 and 3.

^b Fatal flaw condition for Site 1.

8.7 Results

The results of the analysis are presented in Table 8-8. Two sites were identified as having fatal flaws and the remaining seven were ranked in accordance with the overall weighted score.

Rank	Site
1	7
2	9
3	8
4	5
5	4
6	2
7	6
FF	1
FF	3

The top three sites for the Pahala WWTP are:

1. Site 7 (TMK 9-6-002:18)
2. Site 9 (TMK 9-6-002:49)
3. Site 8 (TMK 9-6-002:21)

Site 7 is preferred to the second and third ranked sites for the following reasons:

- A preliminary Archaeological Inventory Survey has been performed for Site 7, indicating no unmitigable cultural sites on the property.
- Site 8 is bisected by an intermittent stream bed, and a steep gulch borders the property to the west.
- Site 7 is closer to the existing collection area than both Site 8 and Site 9.
- Power and potable water are more readily available to Site 7. Site 9 will require the utilities to cross the highway.

8.8 Conclusion

Based on the analysis, Site 7 (TMK 9-6-002:18) was selected as the preferred location for the Pahala WWTP.

Section 9

References

- CH2MHILL. Kau High School and Pahala Elementary School Connection to County Sewer. July 2017.
- County of Hawaii. Letter to Community Homeowners, signed by Mayor Harry Kim. November 5, 2004.
- Crites, Ron, and George Tchobanoglous. *Small and Decentralized Wastewater Management Systems*. WCB McGraw-Hill, 1998.
- Crites, Ronald W., E. Joe Middlebrooks, Robert K. Bastian, and Sherwood C. Reed. "Natural Wastewater Treatment Systems, Second Edition". CRC Press, 2014.
- Crites, Ronald W., E. Joe Middlebrooks, Sherwood C. Reed. *Natural Wastewater Treatment Systems*. CRC Taylor & Francis, 2006.
- Crites, Ronald W., Sherwood C. Reed, and Robert K. Bastian. "Land Treatment Systems for Municipal and Industrial Wastes". McGraw-Hill, 2000.
- Department of Planning, County of Hawaii. Kau Community Development Plan. October 2017.
- Department of Wastewater Management, City and County of Honolulu, State of Hawaii. *Design Standards of the Department of Wastewater Management, Volume 1 and 2*. July 2017.
- Great Lakes – Upper Mississippi River Board of State and Provincial Public Health and Environmental Managers. *Recommended Standards for Wastewater Facilities*. 1997.
- Hawaii Administrative Rules (HAR), Title 11, Department of Health Administrative Rules.
- Masa Fujioka & Associates. Letter Report, Probing for Large Cavities (Lava Tubes), Naalehu and Pahala Large Capacity Cesspool Sewerage System. January 9, 2007.
- M&E Pacific, Inc. Kau Sewer System Evaluation, Kau, Island of Hawaii, Hawaii. December 2004.
- Reed, Sherwood C., Ronald W. Crites, E. Joe Middlebrooks. *Natural Systems for Waste Management and Treatment*. McGraw-Hill, Inc. 1995.
- Rich, Linvil G. *High Performance Aerated Lagoon Systems*. American Academy of Environmental Engineers, 1999.
- SSFM International, Inc. Final Preliminary Engineering Report for Naalehu and Pahala Large Capacity Cesspool Conversion Projects, July 2007.
- USEPA. "Process Design Manual, Land Treatment of Municipal Wastewater Effluents". EPA/625/R-06/016. September 2006.
- Water Environment Federation. *Wastewater Disinfection, Manual of Practice FD-10*. Water Environment Federation, 1996.
- Water Pollution Control Federation. *Aeration, Manual of Practice FD-13*. 1988.
- White, George Clifford, *Handbook of Chlorination and Alternative Disinfectants*, John Wiley & Sons Inc., New York, 1999.

This page intentionally left blank.

Appendix A: Cost Estimates

This page intentionally left blank.

County of Hawaii Department of Environmental Management

Pahala WWTP

Preliminary Design - Order of Magnitude Construction Cost

Electrical and instrumentation	\$	1,976,000
Headworks	\$	906,000
Odor Control	\$	412,000
Lagoons	\$	2,222,000
Wetland	\$	611,000
Land Application	\$	925,000
On-site improvements	\$	6,325,000
Off-site improvements	\$	1,223,000
Total Estimated Construction Cost	\$	14,600,000

Description	Quantity	Units	Unit Cost	Extension
Clear and grub	18.0	AC	\$5,995	\$107,910
BMP's	18.0	AC	\$13,080	\$235,440
Archaeological Monitoring	18	AC	\$2,507	\$45,126
Earthwork	52,000	CY	\$25	\$1,300,000
Sewerline extension	700	LF	\$218	\$152,600
Operations building	1,500	SF	\$500	\$750,000
Generator and tank	1	LS	\$250,000	\$250,000
Fencing	3,200	LF	\$164	\$523,200
Paving	38,000	SY	\$55	\$2,071,000
Off-site waterline	2,500	LF	\$327	\$817,500
On-site waterline	900	LF	\$164	\$147,150
On-site fireline	750	LF	\$218	\$163,500
Off-site overhead electrical	1	LS	\$50,000	\$50,000
Trees (landscaping & Irrigation)	10	EA	\$2,500	\$25,000
Headworks	1	EA	\$501,339	\$501,339
Odor control unit	1	EA	\$329,797	\$329,797
Lagoons	1	LS	\$1,816,902	\$1,816,902
Constructed Wetland	1	LS	\$489,000	\$489,000
Chlorine contact tank	1	LS	\$150,000	\$150,000
Chlorine feed system	1	LS	\$26,577	\$26,577
Land Application piping	2,700	LF	\$125	\$337,500
Land Application trees/ground cover	5.5	AC	\$5,000	\$27,500
Effluent flow meter and sampler	1	LS	\$154,780	\$154,780
			Subtotal	\$10,472,000
			On-site electrical	15%
			Mobilization/Demobilization	1.0%
			Total	\$12,148,000
			Contingency	20%
TOTAL ORDER OF MAGNITUDE CONSTRUCTION COST				\$14,600,000.00

County of Hawaii Department of Environmental Management

Pahala WWTP

Preliminary Options Assessment - Capital Costs

Wetlands

Description	Quantity	Units	Unit Cost	Extension
linear	13,100	SF	\$4	\$52,400
gravel	1,000	CY	\$50	\$50,000
pipng	500	LF	\$100	\$50,000
Effluent Structure	1	EA	\$50,000	\$50,000
Standpipe	1	EA	\$25,000	\$25,000
plantings	13,100	sf	\$20	\$262,000
			Subtotal	\$489,000

County of Hawaii Department of Environmental Management

Pahala WWTP
Options Assessment Cost Summary

Capital Costs

Option No.	Treatment	Disposal	Recycling	Capital Cost (\$M)						Total (\$M)			
				Lagoons	R-1	Limit of TT	Disposal	Reservoir	Diurnal Tank		R-1 Pumps	R-1 Pipelines	
1	Aerated lagoons/wetland/disinfection	Land application	None	10.8				3.8					14.6
2	MBR (R-1)	Land application	None		14.6			3.8					18.4
3	MBR (R-1)	Land application	Seasonal (25% of total annual flow)		14.6			3.8					20.2
4	MBR (R-1)	Land application	Annual storage reservoir (100% of flow)		14.6			3.8	6.1				30.4
5	Limit of treatment technology	Land application	Seasonal (25% of total annual flow)			20.4		3.8					26.0

Annual O&M Costs

No.	Treatment	Disposal	Recycling	Annual O&M Costs (\$)						Total
				Labor	Electricity	Chemicals	Maintenance	Sludge Mgmt		
1	Aerated lagoons/wetland/disinfection	Land application	None	\$42,000	\$118,000	\$12,000	\$54,000	\$10,000	\$236,000	
2	MBR (R-1)	Land application	None	\$582,000	\$345,000	\$10,000	\$73,000	\$42,000	\$1,052,000	
3	MBR (R-1)	Land application	Seasonal (25% of total annual flow)	\$582,000	\$348,000	\$10,000	\$73,000	\$42,000	\$1,055,000	
4	MBR (R-1)	Land application	Annual storage reservoir (100% of flow)	\$582,000	\$356,000	\$10,000	\$73,000	\$42,000	\$1,063,000	
5	Limit of treatment technology	Land application	Seasonal (25% of total annual flow)	\$874,000	\$348,000	\$35,000	\$102,000	\$62,000	\$1,421,000	

Annual Recycled Water Sales

No.	Treatment	Disposal	Recycling	Annual R-1 Water Sales	
				High Price	Low Price
1	Aerated lagoons/wetland/disinfection	Land application	None	\$0	\$0
2	MBR (R-1)	Land application	None	\$0	\$0
3	MBR (R-1)	Land application	Seasonal (25% of total annual flow)	\$17,000	\$9,000
4	MBR (R-1)	Land application	Annual storage reservoir (100% of flow)	\$68,000	\$38,000
5	Limit of treatment technology	Land application	Seasonal (25% of total annual flow)	\$17,000	\$9,000

Equipment Replacement at 20-Years

No.	Treatment	Disposal	Recycling	Equipment Replacement
1	Aerated lagoons/wetland/disinfection	Land application	None	\$2,693,000
2	MBR (R-1)	Land application	None	\$3,653,000
3	MBR (R-1)	Land application	Seasonal (25% of total annual flow)	\$3,653,000
4	MBR (R-1)	Land application	Annual storage reservoir (100% of flow)	\$3,653,000
5	Limit of treatment technology	Land application	Seasonal (25% of total annual flow)	\$5,097,000

**County of Hawaii Department of Environmental Management
Pahala WWTP
Preliminary Options Assessment - Capital Costs**

Common Capital Inputs

Current ENRCCI:	10870
Area markup factor:	30%
Contingency factor:	20%
Project soft costs factor:	25%

Lagoon-Wetland Treatment

Description	Quantity	Units	Unit Cost	Extension
Clear and grub	8	AC	\$15,000	\$120,000
BMPs	8	AC	\$13,000	\$104,000
Earthwork	9,500	CY	\$25	\$237,500
Sewer extension	700	LF	\$160	\$112,000
Headworks	1	EA	\$500,000	\$500,000
Lagoons	1	LS	\$1,800,000	\$1,800,000
Wetlands	1	LS	\$350,000	\$350,000
Chlorine contact tank	1	LS	\$100,000	\$100,000
Chlorine feed system	1	LS	\$30,000	\$30,000
Operations building	1,500	SF	\$500	\$750,000
Generator and tank	1	LS	\$250,000	\$250,000
Fencing	1,500	LF	\$100	\$150,000
Paving	15,000	SY	\$55	\$825,000
Water line extension	1,500	LF	\$160	\$240,000
Yard piping	1	LS	\$200,000	\$200,000
Miscellaneous site work	1	LS	100,000	\$100,000
HELCO power	1	LS	50,000	\$50,000
Hawaiian Telcom	1	LS	20,000	\$20,000
Archeological monitoring	8	AC	2,500	\$20,000
Visual buffer trees and irrigation	10	EA	2,500	\$25,000

Subtotal				\$5,983,500
Electrical and instrumentation			20%	\$1,196,700
Total construction				\$7,180,200
Contingency				\$1,436,040
Total construction				\$8,616,240
Project soft costs				\$2,154,060
Total project cost:				\$10.770 million

Land Application

Description	Quantity	Units	Unit Cost	Extension
Clear and grub	6	AC	\$15,000	\$82,500
BMPs	6	AC	\$13,000	\$71,500
Earthwork	33,500	CY	\$25	\$837,500
Fencing	1,700	LF	\$100	\$170,000
Paving	23,000	SY	\$30	\$690,000
Yard piping	3,500	LF	\$160	\$560,000
Planting	6	AC	10,000	\$60,000
Effluent flow meter and sampler	1	LS	50,000	\$50,000
Archeological monitoring	6	AC	2,500	\$15,000

Subtotal				\$2,536,500
Electrical and instrumentation			0%	\$0
Total construction				\$2,536,500
Contingency				\$507,300
Total construction				\$3,043,800
Project soft costs				\$760,950
Total project cost:				\$3.805 million

R-1 Treatment

Capacity:	0.19 mgd
Mainland cost at current ENRCCI:	\$39.44 /gpd
Local construction cost:	\$51.27 /gpd
Construction estimate:	\$9.7 million
Contingency:	\$1.9 million
Total construction cost:	\$11.7 million
Project soft costs:	\$2.9 million
Total project cost:	\$14.6 million

from R-1 WWRF capital regression. $y=24.003*(x^{-0.299})$

Limit of Treatment Technology

ENRCCI of estimate:	8952
10 mgd WWTP cost:	\$13.80 /gpd
10 mgd WWTP cost at current ENRCCI:	\$16.76 /gpd
Local 10 mgd WWTP cost:	\$21.78 /gpd
Small flow escalation:	\$71.54 /gpd
Construction estimate:	\$13.6 million
Contingency:	\$2.7 million
Total construction cost:	\$16.3 million
Project soft costs:	\$4.1 million
Total project cost:	\$20.4 million

$y=43.47x^{-0.3}$ Per WERF analysis. BNR + advanced nutrient removal

Seasonal Storage Reservoir

Volume:	124 ac-ft
Mainland construction cost:	\$25,000 /ac-ft
Subtotal:	\$3.1 million
Local construction cost:	\$4.0 million
Contingency:	\$0.8 million
Total construction cost:	\$4.8 million
Project soft costs:	\$1.2 million
Total project cost:	\$6.1 million

Diurnal R-1 Tank - Seasonal Program

Volume:	0.19 mgal
Local construction cost:	\$3.00 /gallon
Subtotal:	\$0.6 million
Contingency:	\$0.1 million
Total construction cost:	\$0.7 million
Project soft costs:	\$0.1 million
Total project cost:	\$0.8 million

1 peak day

Diurnal R-1 Tank - Reservoir Program

Volume:	0.77 mgal
Local construction cost:	\$3.00 /gallon
Subtotal:	\$2.3 million
Contingency:	\$0.5 million
Total construction cost:	\$2.8 million
Project soft costs:	\$0.69 million
Total project cost:	\$3.5 million

1 peak day

R-1 Delivery Pumps - Seasonal Program

Peak day flow	0.19 mgal
Delivery time:	8 hours
Pumping capacity:	396 gpm
Mainland construction cost @ ENRCCI 4500:	\$100,000
Current mainland construction cost:	\$242,000
Local construction cost:	\$315,000
Contingency:	\$63,000
Total construction cost:	\$378,000
Project soft costs:	\$94,500
Total project cost:	\$0.5 million

R-1 Delivery Pumps - Reservoir Storage

Peak day flow	0.77 mgal
Delivery time:	8 hours
Pumping capacity:	1604 gpm
Mainland construction cost @ ENRCCI 4500:	\$200,000
Current mainland construction cost:	\$483,000
Local construction cost:	\$628,000
Contingency:	\$125,600
Total construction cost:	\$753,600
Project soft costs:	\$188,400
Total project cost:	\$1.0 million

R-1 Pipelines - Seasonal Program

Peak delivery rate:	396 gpm
Pipeline diameter:	6 inches
Hawaii construction cost:	\$25 /in-ft
Estimated length:	2000 feet
Local construction cost:	\$300,000
Contingency:	\$60,000
Total construction cost:	\$360,000
Project soft costs:	\$90,000
Total project cost:	\$0.5 million

R-1 Pipelines - Reservoir Storage

Peak delivery rate:	1604 gpm
Pipeline diameter:	10 inches
Hawaii construction cost:	\$25 /in-ft
Estimated length:	4000 feet
Local construction cost:	\$1,000,000
Contingency:	\$200,000
Total construction cost:	\$1,200,000
Project soft costs:	\$300,000
Total project cost:	\$1.5 million

County of Hawaii Department of Environmental Management

Pahala WWTP
Preliminary Options Assessment
O&M Costs

Common O&M Inputs

Labor cost:	\$100	/hr (loaded)
FTE effective labor:	1,560	hours/year
Chlorine tab cost:	\$4	/lb
Alum cost:	\$2	/lb
Electricity cost:	\$0.35	/kWh
Maintenance cost:	2%	/year of equipment capital
Sludge management cost:	\$1,500	/dry ton, dewatering, hauling, tip fee
Average flow:	0.19	mgd

Lagoon Treatment/Wetlands/Disinfection

Labor

Normal requirement:	1	visit/week
Operators/visit:	1	
Time per visit:	8	hours/visit
Weekly labor hours:	8	hours/week
Annual labor hours:	416	hours/year
FTEs:	0.3	FTEs
Annual labor cost:	\$41,600	/yr

Electricity

Load	Equiv hp	Percent	kWhr/mo	\$/month
Aerators	50	100%	26,845	\$9,396
Screens	2	10%	107	\$38
Chlorine pumps	0.5	30%	81	\$28
Effluent pumps	2	100%	1,074	\$376
Totals				\$9,837

Annual power cost: \$118,049
Annual power consumption: 337283 kWh/yr

Chemicals

Chlorine dose:	5	mg/L
Daily use:	8	lbs/d
Annual use:	2892	lbs/d
Annual cost:	\$11,568	/yr

Maintenance

Equipment cost:	\$2,692,575	(assume 25% of capital cost)
Annual maintenance:	\$53,852	/yr

Sludge Management

Production rate:	0.1	dry tons/mgal
Annual production:	6.935	/dry tons
Sludge management cost:	\$10,403	/year (deferred for 20 years)

R-1 Treatment

Labor

Normal requirement:	7	visits/week
Operators/visit:	2	
Time per visit:	8	hours/visit
Weekly labor hours:	112	hours/week
Annual labor hours:	5824	hours/year
FTEs:	3.7	FTEs
Annual labor cost:	\$582,400	

Electricity

Daily power use: 2,700 kWh/d
 Annual power use: 985,500 kWh/yr
 Annual power cost: \$344,925/yr

Chemicals

Annual chemical cost: \$10,000

Maintenance

Equipment cost: \$3,652,973 (assume 25% of capital cost)
 Annual maintenance: \$73,059/yr

Sludge Management

Sludge production: 0.4 dry tons/mgal
 Annual production: 28 /dry tons
 Sludge management cost: \$41,610/year

Limit of Treatment Technology**Labor**

Normal requirement: 7 visits/week
 Operators/visit: 3
 Time per visit: 8 hours/visit
 Weekly labor hours: 168 hours/week
 Annual labor hours: 8736 hours/year
 FTEs: 5.6 FTEs
 Annual labor cost: \$873,600

Electricity

Daily power use: 2,700 kWh/d
 Annual power use: 985,500 kWh/yr
 Annual power cost: \$344,925/yr

Chemicals

Alum dose: 30 mg/L
 Alum use: 48 lbs/d
 Alum cost: \$34,703/yr

Maintenance

Equipment cost: \$5,097,397 (assume 25% of capital cost)
 Annual maintenance: \$101,948/yr

Sludge Management

Sludge production: 0.6 dry tons/mgal
 Annual production: 42 /dry tons
 Sludge management cost: \$62,415/year

Seasonal Water Recycling (25%)

Load	Equiv hp	Percent	kWhr/mo	\$/month
R-1 delivery pumps	5	25%	671	\$235
Totals				\$235

Annual power cost: \$2,819

Annual power consumption: 8054 kWh/yr

Annual Water Recycling (100%)

Load	Equiv hp	Percent	kWhr/mo	\$/month
R-1 delivery pumps	5	100%	2,685	\$940
Totals				\$940

Annual power cost: \$11,275

Annual power consumption: 32214 kWh/yr

County of Hawaii Department of Environmental Management
Pahala WWTP

R-1 Sales Assessment

Avoided Cost of Pumping Irrigation Water

Assume pumping from basal lens

Elevation at WWTP:	750	feet MSL
Flow rate:	1000	gpm
	2.2	cfs
Pump efficiency:	85%	
Motor efficiency:	90%	
Power cost:	\$0.35	/kWh
BHP:	223	hp
Motor draw:	185	kW
Unit volume:	1	mgal
Time to pump unit vol:	16.7	hours
Power to pump unit vol:	3080	kWh
Cost to pump unit vol:	\$1,078	

Recycled Water Pricing

High price:	90%	of avoided cost
Low price:	50%	of avoided cost

Recycled Water Sales

High price:	\$970	/mgal
Low price:	\$539	/mgal

Seasonal Recycling Sales

Annual reuse volume:	17	mgal
High price sales:	\$16,661	/year
Low price sales:	\$9,256	/year

100% Recycling Sales

Annual reuse volume:	70	mgal
High price sales:	\$67,987	/year
Low price sales:	\$37,770	/year

**County of Hawaii, DEM
Pahala WWTP Options Assessment
Alternatives Net Present Value Analysis**

Agency:

County of Hawaii, DEM

Project/Problem:

Pahala WWTP Options Assessment

	Risk Premium	Sensitivity Adjustments (%)			Results		
		Benefits	Capital Costs	Other Costs	Capital Cost	30-year NPV	Benefit over Status Quo
Alternative 1					\$14,600,000	(\$21,196,947)	
Alternative 2					\$18,400,000	(\$42,993,152)	(\$21,796,205)
Alternative 3					\$20,200,000	(\$44,496,467)	(\$23,299,520)
Alternative 4					\$30,400,000	(\$53,785,222)	(\$32,588,276)
Alternative 5					\$26,000,000	(\$58,961,593)	(\$37,764,647)
Alternative 6							
Alternative 7							
Alternative 8							
Alternative 9							
Alternative 10							
Alternative 11							
Alternative 12							

Lagoons / wetlands/ disinfection / land application
 R-1 treatment / land application
 R-1 treatment / seasonal recycling (25%)
 R-1 treatment / annual storage res (100%)
 Limit of treatment technology / 25% recycle

Year of analysis:

2017

Escalation rate:

3.20%

Discount rate:

5.50%

Select one

All entries in dollars

All entries in thousands of dollars

Note: "Status quo" refers to

Alternative 1

Make entries in yellow cells only

County of Hawaii Department of Environmental Management

Pahala WWTP
 Preliminary Options Assessment
 Operator Requirement Evaluation

No.	Treatment	Disposal	Recycling
1	Aerated lagoons/disinfection	Land application	None
2	MBR (R-1)	Land application	None
3	MBR (R-1)	Land application	Seasonal (25% of total annual flow)
4	MBR (R-1)	Land application	Annual storage reservoir (100% of flow)
5	Limit of treatment technology	Land application	Seasonal (25% of total annual flow)

Criteria per HAR 11-61	Option				
	1	2	3	4	5
Population served	1	1	1	1	1
Design average flow	1	1	1	1	1
Effluent discharge	2	2	6	6	6
Variation on raw wastes	0	0	0	0	0
Pretreatment	5	10	10	10	10
Primary treatment	0	0	0	0	0
Secondary treatment	8	15	15	15	20
Advanced waste treatment	0	12	12	12	22
Additional treatment processes	7	7	7	7	7
Solids handling	0	19	19	19	19
Disinfection	5	10	10	10	10
Laboratory control bacteriological	0	0	0	0	0
Laboratory control chemical/physical	0	0	0	0	0
Total points	29	77	81	81	96
WWTP Classification per 11-61	I	IV	IV	IV	IV

County of Hawaii Department of Environmental Management
Pahala WWTP
Water Recycling Assessments

Seasonal Recycling with Disposal

Average flow: 0.19 mgd
Irrigated acreage: 6.2 acres

Month	Days	WW Flow (mgal)	Irrig Demand		Disposal (mgal)
			(gpd/ac)	(mgal)	
Jan	31	5.9	0	0.0	5.9
Feb	28	5.3	0	0.0	5.3
Mar	31	5.9	0	0.0	5.9
Apr	30	5.7	644	1.2	4.5
May	31	5.9	2,244	4.3	1.6
Jun	30	5.7	3,043	5.7	0.0
Jul	31	5.9	1,348	2.6	3.3
Aug	31	5.9	1,452	2.8	3.1
Sep	30	5.7	334	0.6	5.1
Oct	31	5.9	0	0.0	5.9
Nov	30	5.7	0	0.0	5.7
Dec	31	5.9	0	0.0	5.9
Totals	365	69.35		17	52

Recycling efficiency: 25%

Recycling with Annual Storage Reservoir

Average flow: 0.19 mgd
Irrigated acreage: 25.3 acres
Reservoir surface area: 6.4 acres
Reservoir pan coefficient: 0.7

Month	Days	WW Flow (mgal)	Irrig Demand (gpd/ac)	Irrig Demand (mgal)	WW in (mgal)	Precipitation in		Evap out (mgal)	Delta Storage (mgal)	Cumulative Storage		Water Depth (feet)
						(inches)	(mgal)			(mgal)	(ac-ft)	
Jan	31	5.9	0	0.0	5.9	5.98	1.0	3.2	6.4	28.1	86.3	13.5
Feb	28	5.3	0	0.0	5.3	3.77	0.7	3.2	5.4	33.5	102.9	16.1
Mar	31	5.9	0	0.0	5.9	5.45	0.9	3.5	6.2	39.8	122.0	19.1
Apr	30	5.7	644	4.9	0.8	3.23	0.6	3.8	0.7	40.5	124.2	19.4
May	31	5.9	2,244	17.6	-11.7	1.94	0.3	3.9	0.7	28.4	87.3	13.6
Jun	30	5.7	3,043	23.1	-17.4	1.56	0.3	4.2	-12.1	10.6	32.5	5.1
Jul	31	5.9	1,348	10.6	-4.7	3.27	0.6	4.5	-4.9	5.7	17.5	2.7
Aug	31	5.9	1,452	11.4	-5.5	3.08	0.5	4.4	-5.7	0.0	0.0	0.0
Sep	30	5.7	334	2.5	3.2	3.6	0.6	3.9	3.1	3.1	9.6	1.5
Oct	31	5.9	0	0.0	5.9	3.98	0.7	3.5	6.0	9.1	27.9	4.4
Nov	30	5.7	0	0.0	5.7	6.7	1.2	3.1	6.3	15.4	47.3	7.4
Dec	31	5.9	0	0.0	5.9	5.82	1.0	3.2	6.3	21.7	66.7	10.4
Totals	365	69.35		70		48.4	8.4		7.7	0.0		

Recycling efficiency: 101%

Peak demand: 23.1 mgal/mo
0.77 mgd

Max Volume: 40 Mgal
124 ac ft